### INSTRUCTION MANUAL

# STANDARD RACK (2 chs. use)

model

**10BXU** 

Thank you for choosing us. Before use, check specifications on the unit label.

If you have any problems or questions with the product, please contact our sales office or representatives.


# General Description

The 10-RACK Model 10BXU can receive up to 2 modules of 10-RACK signal conditioners.

• 24V DC power supply to each module via card-edge connector


#### Installation [Scale: mm(inch)]

- • Operating temperature: -5 to +55°C (23 to 131°F) 50°C (122°F) max. for AC power supply type
- Operating humidity: 30 to 90% RH (non-condensing) Keep away from water, corrosive gas, dust and vibration. Mounting dimensions are as in the below.



#### Terminal Connections

Make wiring to terminals as shown in the figure below.



# Checking I

- A) Terminal Wiring
- B) Power supply voltage: Check voltage across the terminals 5 (+) 6 (-) with a voltmeter.
- C) Installation conditions: Check ambient temperature. Check also that there are not excessive dust particles around. Check that there is no vibration.