# THERMOCOUPLE INPUT MODULE

(high-accuracy, 2 points, Tension clamp)

MODEL R6S-TS2A

## **BEFORE USE ....**

Thank you for choosing us. Before use, please check contents of the package you received as outlined below. If you have any problems or questions with the product, please contact our sales office or representatives.

#### **■ PACKAGE INCLUDES:**

Thermocouple input module (body + 2 CJC sensors)......(1)

#### ■ MODEL NO.

Confirm Model No. marking on the product to be exactly what you ordered.

#### **■ INSTRUCTION MANUAL**

This manual describes necessary points of caution when you use this product, including installation, connection and basic maintenance procedures.

The unit is programmable using the PC Configurator Software. For detailed information on the PC configuration, refer to the R6CON users manual. The R6CON PC Configurator Software is downloadable at our web site.

## **POINTS OF CAUTION**

#### **■** HOT INSERTION/REMOVAL OF MODULES

• Removing or replacing modules does not affect other modules on the same backplane. It is possible to replace them without removing the power supply. However, replacing multiple modules at once may greatly change line voltage levels. We recommend that you replace them one by one.

#### **■ GENERAL PRECAUTIONS**

• Do NOT set the switches while the power is supplied. The switches are used only for maintenance without the power.

## **■** ENVIRONMENT

- Indoor use.
- When heavy dust or metal particles are present in the air, install the unit inside proper housing with sufficient ventilation.
- Do not install the unit where it is subjected to continuous vibration. Do not subject the unit to physical impact.
- Environmental temperature must be within -10 to +55°C (14 to 131°F) with relative humidity within 30 to 90% RH in order to ensure adequate life span and operation.


#### **■** WIRING

- Do not install cables close to noise sources (relay drive cable, high frequency line, etc.).
- Do not bind these cables together with those in which noises are present. Do not install them in the same duct.

#### ■ AND ....

• The unit is designed to function as soon as power is supplied, however, a warm up for 10 minutes is required for satisfying complete performance described in the data sheet.

# **COMPONENT IDENTIFICATION**





## INSTALLATION

Mount the unit on the base (model: R6S-BS).

# **EXTERNAL VIEWS**

## • Front View (cover opened)





#### **■ INDICATOR LED**

ID	COLOR	FUNCTION
Power	OFF	Power supply is off
	Green ON	Power supply is on.
Status	OFF	Standing by (at the startup) or communication error
	Green ON	Normal communication
	Green blink	Configuration mode
	Red ON	DIP switch error
	Red blink	Parameter error
	2 sec. interval	
	Red blink	Burnout
	0.5 sec. interval	

## **■ MODULE ADDRESS**

Module address is selectable between 0 and 31. Choose 0 or 16 with SW1 for offsetting the address selected with SW2 (0 to F, hexadecimal).

The module's slot position on the base and the module address are not necessarily correlated.

SW1	SW2	ADDRESS	SW1	SW2
0	0	16	16	0
0	1	17	16	1
0	2	18	16	2
0	3	19	16	3
0	4	20	16	4
0	5	21	16	5
0	6	22	16	6
0	7	23	16	7
0	8	24	16	8
0	9	25	16	9
0	A	26	16	A
0	В	27	16	В
0	C	28	16	C
0	D	29	16	D
0	E	30	16	E
0	F	31	16	F
	0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 1 0 2 0 3 0 4 0 5 0 6 0 7 0 8 0 9 0 A 0 B 0 C 0 D 0 E	0     0     16       0     1     17       0     2     18       0     3     19       0     4     20       0     5     21       0     6     22       0     7     23       0     8     24       0     9     25       0     A     26       0     B     27       0     C     28       0     D     29       0     E     30	0         0         16         16           0         1         17         16           0         2         18         16           0         3         19         16           0         4         20         16           0         5         21         16           0         6         22         16           0         7         23         16           0         8         24         16           0         9         25         16           0         A         26         16           0         B         27         16           0         C         28         16           0         D         29         16           0         E         30         16

#### **■ OPERATING MODE**

(\*) Factory setting

## • Thermocouple Type

	INPUT 1			INPUT 2		
T/C	SW3			SW3		
	1	2	3	4	5	6
K (CA) (*)						
E (CRC)						
J (IC)						
T (CC)						
B (RH)						
R						
S						
C (WRe 5-26)						

Use PC Configurator Software (model: R6CON) to set N, U, L, P (Platinel II) and PR thermocouples.

■ = ON, Blank = OFF

#### Burnout

BURNOUT	SW3-7
Upscale (*)	
Downscale	

 $\blacksquare$  = ON, Blank = OFF

## Configuration Mode


CONFIGURATION MODE	SW3-8
DIP SW (*)	
PC	

 $\blacksquare$  = ON, Blank = OFF

# **TERMINAL CONNECTIONS**


Connect the unit as in the diagram below or refer to the connection diagram on the side of the unit.

#### ■ EXTERNAL DIMENSIONS unit: mm (inch)




\*Use a minus screwdriver: tip width 3.8 mm max., tip thickness 0.5 to 0.6 mm

#### **■ CONNECTION DIAGRAM**



#### Unused Input Channels

Close across the unused input terminals as shown below. (Choose  $K\ (CA)$  thermocouple for unused channels.)



If unused input terminals are not short-circuited, status indicator LED blinks in red (0.5 sec. cycle), and a burnout flag is set in the PLC or the host device.

#### **■ WIRING INSTRUCTIONS**

• Applicable wire size

Solid: 0.2 to 2.5 mm<sup>2</sup> (0.55 to 1.75 dia.)

Stranded: 0.2 to  $2.5~\mathrm{mm^2}$  (Tinning wire ends may cause


contact failure and therefore is not recom-

mended.)


Ferruled: 0.2 to 1.5 mm $^2$  (0.55 to 1.35 dia.)

• Expose wire conductors by 8 mm (0.31").


#### • How to Connect Wires



1) Insert a minus screwdriver into the wire entry opening, between the clamp and the housing, until its tip hits the bottom where it is firmly held.




2) Insert a wire. Push the screwdriver toward the direction indicated with the arrow in the figure below to widen the opening if necessary.



3) Confirm that the wire tip hits the bottom and pull out the screwdriver in holding it in position.

Confirm that the wire's insulation tube is not caught in the clamp.



# **PC CONFIGURATOR**

With configurator software, settings shown below are available.

Refer to the software manual of R6CON for detailed operation.

#### **■ CHANNEL INDIVIDUAL SETTING**

PARAMETER	AVAILABLE RANGE	DEFAULT SETTING	
Sensor type	K (CA) E (CRC) J (IC) T (CC) B (RH) R	K (CA)	
	S C (WRe 5-26) N U L P (Platinel II) (PR)		
Lower range value	Depends on sensor type	0.00 (degC)	
Upper range value	Depends on sensor type	0.00 (degC)	
Fine zero adjustment	-320.00 to +320.00 (%)	0.00 (%)	
Fine gain adjustment	-3.2000 to +3.2000	1.0000	
Scaled range Zero	-32000 to +32000	0	
Scaled range Span	-32000 to +32000	10000	
Burnout	Upscale, Downscale	Upscale	

## **■ CHANNEL BATCH SETTING**

PARAMETER	AVAILABLE RANGE	DEFAULT SETTING	
Loss of internal bus	0.0 – 99.9 (sec.)	1.0 (sec.)	
communication detec-			
tion time			
Conversion rate	250, 500 (msec.)	500 (msec.)	
Temperature unit	degC, degF, K	degC	
CJC	ON, OFF	ON	
Limit	-15 to +115%	-15 to +115%	
	Scaled range Zero / Span		