

Remote I/O R7 Series
LNS PLUG-IN SOFTWARE
Model: R7LX2PLG

Users Manual

CONTENTS

1. GENERAL	3
1.1 R7L REMOTE I/O FEATURES	3
1.2 R7LX2PLG SOFTWARE	3
1.3 HARDWARE REQUIREMENTS	3
1.4 INSTALLING & DELETING THE PROGRAM	4
2. BASIC OPERATIONS	5
2.1 STARTING / QUITTING THE R7LX2PLG	5
2.2 VIEW COMPONENTS AND FUNCTIONS	6
2.3 HOW TO SET UP PARAMETERS	7
3. FUNCTIONAL BLOCK CONFIGURATION PROPERTY	8
3.1 NodeObject	8
3.2 fbDO[0...7]	9
3.3 fbDI[0...7]	10
3.4 fbCMP[0...7]	11
3.5 fbCNT[0...7]	12
3.6 fbEN[0...3]	13
3.7 fbTMR[0,1]	14
3.8 fbDOEX[0...7]	15
3.9 fbDIEX[0...7]	16
3.10 fbSV[0...3]	17
3.11 fbTS[0...3]	18
3.12 fbRS[0...3]	19
3.13 fbYV[0,1]	20
3.14 fbYS[0,1]	21
3.15 fbCV[0...3]	22
3.16 fbARM[0...3]	23
3.17 fbLED[0]	24
3.18 fbRR[0,1]	24

1. GENERAL

This document explains how to use LNS Plug-in Software model R7LX2PLG, which is usable on Echelon LonMaker Integration Tool.

Please refer also to manuals provided with LonMaker when you need to know its detailed functions.

1.1 R7L REMOTE I/O FEATURES

The R7L, interfacing with LONWORKS network, can send local contact I/O and analog I/O signal status to other devices on the network. Furthermore, various functions as listed below can be programmed using LonMaker.

- Accumulating ON/OFF counts and ON/OFF time
- Comparing two discrete inputs
- One-shot output
- Four-input, single-output encoder
- Simple timer function, generating cyclic pulse signals
- Alarm output

1.2 R7LX2PLG SOFTWARE

The R7LX2PLG, plug-in software used on LonMaker, helps you easily program various functional blocks.

1.3 HARDWARE REQUIREMENTS

- LonMaker Turbo Edition Ver.3.2 or higher + LonMaker Turbo Service Pack 4.0 or higher
- LonMark Resource File Ver.13 or higher
- PC/AT compatible personal computer with specifications required by LonMaker (It may not cover all required conditions.)
- LONWORKS interface (compatible to FTT-10A) compatible with the above PC

1.4 INSTALLING & DELETING THE PROGRAM

The program, provided as compressed archive, can be downloaded at our web site. Decompress the archive first.

■ INSTALL

The plug-in software must be registered on LonMaker during its installation procedure. Once registered, LonMaker executes a procedure to register the R7LX2PLG as the R7L's Device Template every time it creates new Network. (Except when the R7LX2PLG is disabled on LonMaker.)

Installing the R7LX2PLG

This procedure is necessary only once when you start using the R7LX2PLG.

Decompress the archive and execute 'setup.exe' to start up the R7LX2PLG installer program. Follow instructions on the Windows.

CAUTION !

Do not attempt installing the R7LX2PLG while LNS software programs such as LonMaker, LNS DDE Server, are running.

CAUTION !

If you have already the program installed in your PC, remove it before installing a new one.

Registering the necessary DLL file to the PC

(This procedure is necessary when the OS is Windows 7 32-bit and 'msstdfmt.dll' is not installed in C:\Windows\system32.)

- (1) Locate the DLL file in the folder decompressed with the above procedure. Copy 'msstdfmt.dll' to C:\Windows\system32. (It is necessary to log on as a administrator.)
- (2) Click <Start> button and then click [accessories]. Right click [Command Prompt] then select 'Run as administrator.'
- (3) Enter 'regsvr32 C:\windows\system32\msstdfmt.dll' and execute with Enter key.

Registering the R7LX2PLG on a new Network created by LonMaker

Locate the XIF file for the R7L device and choose one of the files. Other XIF files on the same directory are automatically registered when choosing one.

If an error occurs, delete all Device Templates on the Network before trying to install them again.

CAUTION !

XIF files must be in the same directory as for the R7LX2PLG in order to register all of them at once with the R7LX-2PLG on new Network.

■ DELETE

Open [Control Panel > Add/Remove Programs]. Select [R7LX2PLG] from the program list and click <Delete> button.

CAUTION !

Do not attempt deleting the R7LX2PLG while LNS software programs such as LonMaker, LNS DDE Server, are running.

■ UPDATE

Remove the old version before you install an updated version of the program.

2. BASIC OPERATIONS


2.1 STARTING / QUITTING THE R7LX2PLG

Display images shown in this manual may change in detail when the software version is updated.


■ STARTING THE R7LX2PLG

Choose the R7L device's Functional Block on LonMaker (Microsoft VISIO). Click the right mouse button and choose 'Configure' to open the R7L Plug In for LonMaker.

Choosing Configure



R7LX2PLG view




■ QUITTING THE R7LX2PLG

Choose [X] at the right end of the title bar to quit the program.

2.2 VIEW COMPONENTS AND FUNCTIONS

The R7LX2PLG view is composed of the device information on the top, Functional Block list at the left, and the Functional Block configuration at the right.



View Components

Components	Function
Device Name	Identification of the device currently called up on the window.
Device Template	Device template of the device currently called up on the window. LONWORKS program ID shown in ()
Device Status	Status of the device currently called up on the window. Not Commissioned Yet Cnfg Bypass: Offline Cnfg Online: Online
Connected Device	Device ID acquired from the connected device
Serial	Serial number acquired from the connected device
Location	Location information acquired from the connected device (Not identical to the information stored in NeuronChip)
Select FB	Selection list to show Functional Block on the FB configuration window to the right.

Buttons

<Read value from Database>	Used to read setting from the Database on the Network
<Read value from Device>	Used to read setting from the connected Device
<Apply to Database>	Used to apply the setting to the Database on the Network
<Apply to Database And Device>	Used to apply the setting to the Database on the Network and the connected Device

2.3 HOW TO SET UP PARAMETERS


- (1) Choose Functional Block from the list on the left side to call up the parameters on the FB configuration window on the right.
- (2) Click <Read value from Database> or <Read value from Device> to call up the current setting.
- (3) Modify values as needed.
- (4) Click <Apply to Database> or <Apply to Database And Device> to store the new setting.

LonMaker Network Database retains Configuration Property of each LONWORKS Device even when the information is not saved in the Device. When the Device is connected, the new information is applied to it.

<Read value from Database> and <Apply to Database> buttons are available when the Device is not connected, while <Read value from Device> and <Apply to Database And Device> buttons are available when it is.

3. FUNCTIONAL BLOCK CONFIGURATION PROPERTY

3.1 NodeObject



Parameter	Function
nvoABNLCond	Shows the device status (All 0s in normal conditions). Bit 0 through Bit 3 : Input overrange error ($\leq -15\%$ or $\geq 115\%$) or burnout with Input 0...3 Bit 4 through Bit 7 : ADC error with Input 0...3 Bit 10 : E ² PROM Configuration Property check sum error Bit 11 : E ² PROM Count data check sum error (Bit 10 and Bit 11 can be reset to 0 by pressing <Clear Error Status> button.) Bit 8, 9, 12 through Bit 15 : Invalid
SCPTlocation	Used to write Tag No. (name); up to 30 characters
Ex Module Select	Setting the extension module (SCPTdirection Bit 0, Bit 1) Power supply must be reset when this configuration property is changed. Set this property before an extension module is connected. No extension module : Without extension module Input Ex module : Discrete input (fb and other settings assigned to the 9th and following points are invalid with 8-point input module.) Output Ex module : Discrete output (fb and other settings assigned to the 9th and following points are invalid with 8-point output module.)
nvoHrtBtCnt Count Up Period (SCPT, pdeHrtBt)	Set the count up period. 0.0 : no count up 1.0 - 3600.0 : period to perform count up
Network Variable Send/Receive Setting	Setting SCPTmaxSendTime (maximum time interval to send network variables) and SCPTminSendTime (minimum time interval to send network variables) per fb. Power supply must be reset when this configuration property is changed. Network variables are sent out in the specified intervals. No sending with 0.0 or when a value less than the minimum value is set. SCPTmaxSendTime is selectable within 0.0 or 10.0...3600.0 seconds. SCPTminSendTime is selectable within 0.0 or 0.2...3600.0 seconds.
<Clear Error Status>	Used to reset E ² PROM Error Status (nvoABNLCond Bit 10 or Bit 11 = 1).

How To Set Network Variables Send/Receive Setting

- (1) Choose Functional Block that you want to modify.
- (2) Enter SCPTmaxSendTime (left) and SCPTminSendTime (right) below the FB list.
- (3) Press <Apply To Database> or <Apply To Database And Device> button to save new settings.

3.2 fbDO[0...7]

Parameter	Function
nviDO nviDOOvr nvoDOStat	<p>Indicates status of nviDO, nviDOOvr and nvoDOStat. Read-in values may not match actual field values.</p> <ul style="list-style-type: none"> • State Mode <p>nviDO : Turns ON (100.0 1) or OFF (0.0) Y0, Y2, Y4, Y6, Y8, YA, YC, YE depending upon this input.</p> <p>nviDOOvr : Turns ON (100.0 1) or OFF (0.0) Y1, Y3, Y5, Y7, Y9, YB, YD, YF depending upon this input.</p> <p>nvoDOStat : Invalid</p> • Momentary Mode 1 or 2 <p>nviDO, nviDOOvr</p> <p>Y0, Y2, Y4, Y6, Y8, YA, YC, YE : One-shot output when the input is ON (100.0 1).</p> <p>Y1, Y3, Y5, Y7, Y9, YB, YD, YF : One-shot output when the input is OFF (0.0).</p> <p>nviDO status is invalid when nviDOOvr is other than 'Invalid.' One-shot output is provided at either Y0 or Y1 depending upon nviDOOvr value.</p> <p>nvoDOStat : Outputs last one-shot output status.</p>
fbDO Operating Mode	<p>fbDO operating mode (SCPTdirection Bit 0)</p> <p>State Mode : ON/OFF status of nviDO, nviDOOvr is output.</p> <p>Momentary Mode 1 or 2 : One-shot output depending upon the ON/OFF status of nviDO, nviDOOvr.</p>
nviDo, nviDOOvr State at Power Startup	<p>Output held or not at power off in State Mode (SCPTdirection Bit 1)</p> <p>OFF (open contact) : OFF at the power startup</p> <p>Restore state before power turned off : Outputs the held status at the power startup</p>
ON Pulse Width	<p>Pulse width of the one-shot output in Momentary Mode 1 or 2 (SCPTtimeout)</p> <p>0.1...60.0 seconds.</p>

3.3 fbDI[0...7]

Parameter	Function																				
nvoDIStat nvoDIArm	<p>Indicates status of nvoDIStat, nvoDIArm. Read-in values may not match actual field values.</p> <ul style="list-style-type: none">• Normal Mode nvoDIStat : Outputs X0 (X2, X4, X6, X8, XA, XC, XE) status. nvoDIArm : Outputs X1 (X3, X5, X7, X9, XB, XD, XF) status.• RS-Flip Flop Mode X0 (X2, X4, X6, X8, XA, XC, XE) : Set signal X1 (X3, X5, X7, X9, XB, XD, XF) : Reset signal When X0 or X1 receives an one-shot signal, fbDI data is set or reset respectively. nvoDIStat outputs ON signal at Set. nvoDIArm outputs ON signal at Reset.• Combination Mode <table><tr><td>X0 X2 X4 X6 X8 XA XC XE</td><td>X1 X3 X5 X7 X9 XB XD XF</td><td>nvoDIStat</td><td>nvoDIArm</td></tr><tr><td>OFF</td><td>OFF</td><td>0.0 0 (OFF)</td><td>Invalid</td></tr><tr><td>ON</td><td>OFF</td><td>100.0 1 (ON)</td><td>Invalid</td></tr><tr><td>OFF</td><td>ON</td><td>0.0 0 (OFF)</td><td>0.0 0 (OFF)</td></tr><tr><td>ON</td><td>ON</td><td>100.0 1 (ON)</td><td>100.0 1 (ON)</td></tr></table>	X0 X2 X4 X6 X8 XA XC XE	X1 X3 X5 X7 X9 XB XD XF	nvoDIStat	nvoDIArm	OFF	OFF	0.0 0 (OFF)	Invalid	ON	OFF	100.0 1 (ON)	Invalid	OFF	ON	0.0 0 (OFF)	0.0 0 (OFF)	ON	ON	100.0 1 (ON)	100.0 1 (ON)
X0 X2 X4 X6 X8 XA XC XE	X1 X3 X5 X7 X9 XB XD XF	nvoDIStat	nvoDIArm																		
OFF	OFF	0.0 0 (OFF)	Invalid																		
ON	OFF	100.0 1 (ON)	Invalid																		
OFF	ON	0.0 0 (OFF)	0.0 0 (OFF)																		
ON	ON	100.0 1 (ON)	100.0 1 (ON)																		
fbDI Operating Mode	<p>fbDI operating mode (SCPTdirection Bit 0, Bit 1) Normal Mode: ON/OFF status of contact input is output at nvoDIStat and nvoDIArm. RS-Flip Flop Mode : RS-Flip Flop operation using the combination of two contact inputs. Combination Mode : nvoDIStat and nvoDIArm status determined by the combination of two contact inputs</p>																				
Invert Contact Logic (nvoDIStat)	<p>nvoDIStat Output (SCPTinvrtOut) ST_OFF : OFF at open contact, ON at closed contact ST_ON : ON at open contact, OFF at closed contact</p>																				
Invert Contact Logic (nvoDIArm)	<p>nvoDIArm Output (SCPTinvrtOut) ST_OFF : OFF at open contact, ON at closed contact ST_ON : ON at open contact, OFF at closed contact</p>																				

3.4 fbCMP[0...7]

fbCMP[0]

fbCMP Network Variables

Input

nviCMPIn1 from Device

nviCMPIn2 from Device

Output

nvoCMPOut from Device

fbCMP Configuration Property

nvoCMPOut Delay Time (SCPTtimeout) (0.1 - 60.0 seconds)

5.0

Read value from Database Read value from Device Apply To Database Apply To Database And Device

Parameter	Function
nviCMPIn1	Indicates status of nviCMPIn1 to be compared Read-in values may not match actual field values.
nviCMPIn2	Indicates status of nviCMPIn2 to be compared Read-in values may not match actual field values.
nvoCMPOut	nviCMPIn1 and nviCMPIn2 are compared. OFF is output when both values are equivalent, ON or 'Invalid' is output when they are not. '100.0 1' (ON) is output when nviCMPIn1 status change caused the discrepancy. '0.0 - 1' (Invalid) is output when nviCMPIn2 status change caused it. '0.0 0' (OFF) is output when nviCMPIn1 and/or nviCMPIn2 is 'Invalid,' regardless of the values of both.
nvoCMPOut Delay Time	Delay time before ON or 'Invalid' is output when a discrepancy occurs between nviCMPIn1 and nviCMPIn2. (SCPTtimeout) Selectable within 0.1...60.0 seconds. OFF is immediately output when nviCMPIn1 and nviCMPIn2 states match, regardless of this setting.

3.5 fbCNT[0...7]

fbCNT01

fbCNT Network Variables

Input

nviCNTIn from Device

nviCNTCtrl from Device

nviCNTPreset from Device

(NvType) SNVT_count_32

Output

nvoCNTOut from Device

(NvType) SNVT_count_32

Count Source nviCNTIn

Count Mode Number of ON counts

Reset Value nvoCNTOut

nvoCNTOut Value at power ON(SCPTdirection.bit7)

Restore value before Power OFF

nviCNTIn Configuration Property

Count Condition (SCPTinvertOut) : ST_OFF

nviCNTCtrl Configuration Property

Power Up State (SCPTpwrUpState) : 100.0 1 (0 0,100 1,0 -1)

nvoCNTOut Configuration Property

Max Count Value(SCPTmaxRnge): 999999999 (100 - 999999999)

Reset Value (SCPTsetpoint) : 0 (0 - 999999999)

Read value from Database Read value from Device Apply To Database Apply To Database And Device

Parameter	Function
nviCNTIn	Indicates status of nviCNTIn Read-in values may not match actual field values.
nviCNTCtrl	Indicates status of nviCNTCtrl Read-in values may not match actual field values.
nvoCNTOut	Indicates status of nvoCNTOut Read-in values may not match actual field values.
(NvType)	Setting Network Variable type for nvoCNTOut SNVT_count_32 (Max 999 999 999) SNVT_count_f (Max. 999 999) When Network Variable type is changed, Configuration Properties are reset to the default values (Max. Count Value to the maximum possible value, Reset Value to 0)
nviCNTPreset	When the value is received, set the value to nvoCNTOut.
(NvType)	Setting Network Variable type for nviCNTPreset (Same type with nvType of nvoCNTOut)
Counted Object	(SCPTdirection Bit 0...Bit 5) nviCNTIn: Counts nviCNTIn status X0...XF : Counts the R7L input signals ExX0...ExXF : Counts the R7L extension module's input signals
Count Function	(SCPTdirection Bit 6) Number of ON counts: Number of status changes from OFF to ON Accumulated time of ON status
Memory Storage at Power	Startup (SCPTdirection Bit 7) Memory storage at the non-volatile memory Retain count : Count retained in the memory and preset at the startup Reset to 0 : Count always reset to 0
Count Logic	Count logic is inverted at nviCNTIn. (SCPTinvrtOut) ST_OFF : Count with nviCNTIn = ON ST_ON : Count with nviCNTIn = OFF
Startup State	Set value applied at nviCNTCtrl when the power supply is turned on. (SCPTpwrUpState) 0.0 0 : Stop counting 100.0 1 : Start counting 0.0 -1 : Reset count value
Max Count	Maximum count value for nvoCNTOut. (SCPTmaxRnge) Count reset to 0 and restarted at overflow. 100 at the minimum, up to the maximum possible count
Reset Value	Preset count to be applied when nvoCNTOut is reset. (SCPTsetpoint) 0 at the minimum, up to the maximum possible count.

<Reset Value nvoCNTOut> Used to manually reset the count values.

3.6 fbEN[0...3]

fbENIO1

fbEN Network Variables

Input

nviENIn1 from Device

nviENIn2 from Device

nviENIn3 from Device

nviENIn4 from Device

Output

nvoENOut from Device

fbEN Configuration Property

Lookup Table (SCTvalueDefinition [0-16]) :

nviEN In1 ,In2 ,In3 ,In4	In1 ,In2 ,In3 ,In4
OFF,OFF,OFF,OFF 0.0 0	OFF,OFF,OFF,ON 0.0 0
ON ,OFF,OFF,OFF 0.0 0	ON ,OFF,OFF,ON 0.0 0
OFF,ON ,OFF,OFF 0.0 0	OFF,ON ,OFF,ON 0.0 0
ON ,ON ,OFF,OFF 0.0 0	ON ,ON ,OFF,ON 0.0 0
OFF,OFF,ON ,OFF 0.0 0	OFF,OFF,ON ,ON 0.0 0
ON ,OFF,ON ,OFF 0.0 0	ON ,OFF,ON ,ON 0.0 0
OFF,ON ,ON ,OFF 0.0 0	OFF,ON ,ON ,ON 0.0 0
ON ,ON ,ON ,OFF 0.0 0	ON ,ON ,ON ,ON 0.0 0
	Invalid in any NV 0.0 0

Read value from Database

Read value from Device

Apply To Database

Apply To Database And Device

Parameter	Function
nviENIn1...nviENIn4	Indicates status of nviENIn1 through nviENIn4 Read-in values may not match actual field values.
nvoENOut	Indicates status of nvoENOut Read-in values may not match actual field values.
Lookup Table	Table that defines output values against each input status

3.7 fbTMR[0,1]

Parameter	Function
nviTMRIn	Indicates status of nviTMRIn Read-in values may not match actual field values.
nvoTMROut	Indicates status of nvoTMROut Read-in values may not match actual field values.
fbTMR Operating Mode	fbTMR operating mode (SCPTdirection Bit 0) One shot mode Cyclic mode
Time Setting	Time parameters <ul style="list-style-type: none"> One shot mode <p>SCPTtimeout[0] : Delay time before nvoTMROut is turned on after nviTMRIn has been turned on. Selectable within 0...800.0 seconds</p> <p>SCPTtimeout[1] : Time to maintain ON status of nvoTMROut after it has been turned on. Selectable within 1.0...800.0 seconds, 800.1(=Latching; No turning off)</p> <p>SCPTtimeout[2] : Delay time before nvoTMROut is turned off after nviTMRIn has been turned off. Selectable within 0.0...800.0 seconds, 800.1(=Latching; No turning off) (With SCPTtimeout[1] also set to '800.1,' nvoTMROut remains on. Set 'Invalid' at nviTMRIn to turn nvoTMROut off.)</p> Cyclic mode <p>SCPTtimeout[0] : Invalid</p> <p>SCPTtimeout[1] : Defines ON-OFF time period. ON and OFF times are equal. One pulse cycle equals twice as long as the set value.</p> <p>SCPTtimeout[2] : Invalid</p>
Timer's Trigger Condition	(SCPTinvrtOut) ST_OFF : Start with nviTMRIn = ON, Stop at OFF ST_ON : Start with nviTMRIn = OFF, Stop at ON
Invert Timer Logic	Inverting the timer output logic (SCPTinvrtOut) ST_OFF : nvoTMROut = ON with the timer functioning and ON, nvoTMROut = OFF in any other conditions. ST_ON : nvoTMROut = OFF with the timer functioning and ON, nvoTMROut = ON in any other conditions.

3.8 fbDOEX[0...7]

Parameter	Function
nviDOEX1	Indicates status of nviDOEX1. Read-in values may not match actual field values. Turns ON (100.0 1) or OFF (0.0) Y0, Y2, Y4, Y6, Y8, YA, YC, YE of the extension module depending upon this input.
nviDOEX2	Indicates status of nviDOEX2. Read-in values may not match actual field values. Turns ON (100.0 1) or OFF (0.0) Y1, Y3, Y5, Y7, Y9, YB, YD, YF of the extension module depending upon this input.
nviDOEX1, nviDOEX2 State at Power Startup	Output held or not at power off (SCPTdirection Bit 1) OFF (open contact) : OFF at the power startup Restore state before power turned off : Outputs the held status at the power startup
Startup State (nviDOEX1)	Setting value applied at nviDOEX1 when the power supply is turned on. (SCPTpwrUpState) Turns ON (100.0 1) or OFF (0.0) Y0, Y2, Y4, Y6, Y8, YA, YC, YE of the extension module depending upon this setting.
Startup State (nviDOEX2)	Setting value applied at nviDOEX2 when the power supply is turned on. (SCPTpwrUpState) Turns ON (100.0 1) or OFF (0.0) Y1, Y3, Y5, Y7, Y9, YB, YD, YF of the extension module depending upon this setting.

3.9 fbDIEX[0...7]

Parameter	Function																																		
nvoDIEX1 nvoDIEX2	Indicates status of nvoDIEX1, nvoDIEX2. Read-in values may not match actual field values. <ul style="list-style-type: none">• Normal Mode nvoDIEX1 : Outputs X0 (X2, X4, X6, X8, XA, XC, XE) status. nvoDIEX2 : Outputs X1 (X3, X5, X7, X9, XB, XD, XF) status.• Combination Mode nvoDIEX1, nvoDIEX2 status output depending upon the combined X0 (X2, X4, X6, X8, XA, XC, XE) and X1 (X3, X5, X7, X9, XB, XD, XF) status. <table><tr><td>X0</td><td>X1</td><td rowspan="8">nvoDIEX1</td><td rowspan="8">nvoDIEX2</td></tr><tr><td>X2</td><td>X3</td></tr><tr><td>X4</td><td>X5</td></tr><tr><td>X6</td><td>X7</td></tr><tr><td>X8</td><td>X9</td></tr><tr><td>XA</td><td>XB</td></tr><tr><td>XC</td><td>XD</td></tr><tr><td>XE</td><td>XF</td></tr><tr><td>OFF</td><td>OFF</td><td>0.0 0 (OFF)</td><td>Invalid</td></tr><tr><td>ON</td><td>OFF</td><td>100.0 1 (ON)</td><td>Invalid</td></tr><tr><td>OFF</td><td>ON</td><td>0.0 0 (OFF)</td><td>0.0 0 (OFF)</td></tr><tr><td>ON</td><td>ON</td><td>100.0 1 (ON)</td><td>100.0 1 (ON)</td></tr></table>	X0	X1	nvoDIEX1	nvoDIEX2	X2	X3	X4	X5	X6	X7	X8	X9	XA	XB	XC	XD	XE	XF	OFF	OFF	0.0 0 (OFF)	Invalid	ON	OFF	100.0 1 (ON)	Invalid	OFF	ON	0.0 0 (OFF)	0.0 0 (OFF)	ON	ON	100.0 1 (ON)	100.0 1 (ON)
X0	X1	nvoDIEX1	nvoDIEX2																																
X2	X3																																		
X4	X5																																		
X6	X7																																		
X8	X9																																		
XA	XB																																		
XC	XD																																		
XE	XF																																		
OFF	OFF	0.0 0 (OFF)	Invalid																																
ON	OFF	100.0 1 (ON)	Invalid																																
OFF	ON	0.0 0 (OFF)	0.0 0 (OFF)																																
ON	ON	100.0 1 (ON)	100.0 1 (ON)																																
fbDI Operating Mode	fbDI operating mode (SCPTdirection Bit 0, Bit 1) Normal Mode: ON/OFF status of contact input is output at nvoDIEX1 and nvoDIEX2. Combination Mode : nvoDIEX1 and nvoDIEX2 status determined by the combination of two contact inputs																																		
Invert Contact Logic (nvoDIEX1)	nvoDIEX1 Output (SCPTinvrtOut) ST_OFF : OFF at open contact, ON at closed contact ST_ON : ON at open contact, OFF at closed contact																																		
Invert Contact Logic (nvoDIEX2)	nvoDIEX2 Output (SCPTinvrtOut) ST_OFF : OFF at open contact, ON at closed contact ST_ON : ON at open contact, OFF at closed contact																																		

3.10 fbSV[0...3]

Parameter	Function
nvoSVVal	Indicates nvoSVVal value in % of the selected range. Read-in values may not match actual field values.
Input Range	Input range for Input 0 through 3 (SCPTsceneNmbr) 0 : -10.00 to 10.00 V 1 : -5.00 to 5.00 V 2 : -1.00 to 1.00 V 3 : 0.00 to 10.00 V 4 : 0.00 to 5.00 V 5 : 1.00 to 5.00 V 6 : 0.00 to 1.00 V 7 : -0.500 to 0.500 V 8 : 0.000 to 0.500 V 9 : -20.00 to 20.00 mA 10 : 4.00 to 20.00 mA 11 : 0.00 to 20.00 mA
Send Delta	Minimum deviation required to send out the network variable (SCPTsndDelta) Selectable within 0.100...100.000
Lower Range Value	nvoSVVal lower range voltage/current in % of the input range (SCPTsetpoint[0]) Selectable within -15.000...115.000%. SCPTsetpoint[0] < SCPTsetpoint[1]
Upper Range Value	nvoSVVal upper range voltage/current in % of the input range (SCPTsetpoint[1]) Selectable within -15.000...115.000%. SCPTsetpoint[0] < SCPTsetpoint[1]
Zero (Offset) Adjustment	nvoSVVal zero (offset) adjustment (SCPToffset) Added to the calculation result with SCPTsetpoint[0,1] and SCPTgain. Selectable within -163.840...163.835%
Span (Gain) Adjustment	nvoSVVal span (gain) adjustment (SCPTgain) Gain = Multiplier / 10000 (Divisor is fixed at 10000.), applied to SCPTsetpoint[0,1]. Selectable within 0...32000

3.11 fbTS[0...3]

Parameter	Function
nvoTSVal	Indicates nvoTSVal value in engineering unit. Read-in values may not match actual field values.
(NvType)	Setting Network Variable type for nvoTSVal SNVT_temp SNVT_temp_p
nvoTSPVal	Indicates status of nvoTSPVal in % of the selected input range. Read-in values may not match actual field values.
Input Sensor Type	Input sensor type for Input 0 through 3 (SCPTsceneNbr) 0 : K (CA) 7 : C (WRe 5-26) 1 : E (CRC) 8 : N 2 : J (IC) 9 : U 3 : T (CC) 10 : L 4 : B (RH) 11 : P (Platinel II) 5 : R 12 : (PR) 6 : S
Reference Point	nvoTSVal reference temperature point to adjust the offset (SCPTOffset[0]) Selectable within -274.0...6279.5°C
Calibrated Value	nvoTSVal temperature value to output when the reference temperature set at SCPTOffset[0] is input. (SCPTOffset[1]) Offset = SCPTOffset[1] – SCPTOffset[0] Selectable within -274.0...6279.5°C
Gain Applied to SCPTOffset[0]	nvoTSVal gain applied to SCPTOffset[0] (SCPTdefScale) Selectable within 80.000...120.000%
Send Delta	Minimum deviation required to send out the network variable (SCPTminDeltaTemp) Selectable within 1.0...327.66
Lower Range Temp	nvoTSVal lower range temperature (SCPTsetpoint[0]) SCPTsetpoint[0] < SCPTsetpoint[1]
Upper Range Temp	nvoTSVal upper range temperature (SCPTsetpoint[1]) SCPTsetpoint[0] < SCPTsetpoint[1]
Zero (Offset) Adjustment	nvoTSPVal zero (offset) adjustment (SCPTOffset) Added to the calculation result with SCPTsetpoint[0,1] and SCPTgain. Selectable within -163.840...163.835%
Span (Gain) Adjustment	nvoTSPVal span (gain) adjustment (SCPTgain) Gain = Multiplier / 10000 (Divisor is fixed at 10000.), applied to SCPTsetpoint[0,1]. Selectable within 0...32000

3.12 fbRS[0...3]

fbRS[0]

fbRS Network Variables

Input Output nvoRSVal from Device
(NvType) SNVT_temp
nvoRSPVal from Device

fbRS Configuration Property

Input Sensor Type (SCPTsceneNmbr) Pt100 IEC/JIS'97

nvoRSVal Configuration Property

Reference point (SCPToffset[0]) 0.0
Calibrated Value (SCPToffset[1]) 0.0
Gain Applied to SCPToffset[0] (SCPTdefScale) 100.000
(80.000-120.000)
Send Delta(SCPTminDeltaTemp) (1.0-327.66) 5.00
Lower Range Temp (SCPTsetpoint[0]) 0.0
Upper Range Temp (SCPTsetpoint[1]) 100.0

nvoRSPVal Configuration Property

Zero (Offset) Adjustment (SCPToffset): 0.000
Span (Gain) Adjustment (SCPTgain multiplier, divisor = 10000): 10000 (0-32000)

Read value from Database Read value from Device Apply To Database Apply To Database And Device

Parameter	Function
nvoRSVal	Indicates nvoRSVal value in engineering unit. Read-in values may not match actual field values.
(NvType)	Setting Network Variable type for nvoRSVal SNVT_temp SNVT_temp_p
nvoRSPVal	Indicates status of nvoRSPVal in % of the selected input range. Read-in values may not match actual field values.
Input Sensor Type	Input sensor type for Input 0 through 3 (SCPTsceneNmbr) 0 : Pt 100 (JIS '97, IEC) 1 : Pt 100 (JIS '89) 2 : JPt 100 (JIS '89) 3 : Pt 50 (JIS '81) 4 : Ni 100 5 : Cu 10 6 : Cu 50
Reference Point	nvoRSVal reference temperature point to adjust the offset (SCPToffset[0]) Selectable within -274.0...6279.5°C
Calibrated Value	nvoRSVal temperature value to output when the reference temperature set at SCPToffset[0] is input. (SCPToffset[1]) Offset = SCPToffset[1] – SCPToffset[0] Selectable within -274.0...6279.5°C
Gain Applied to SCPToffset[0]	nvoRSVal gain applied to SCPToffset[0] (SCPTdefScale) Selectable within 80.000...120.000%
Send Delta	Minimum deviation required to send out the network variable (SCPTminDeltaTemp) Selectable within 1.0...327.66
Lower Range Temp	nvoRSVal lower range temperature (SCPTsetpoint[0]) SCPTsetpoint[0] < SCPTsetpoint[1]
Upper Range Temp	nvoRSVal upper range temperature (SCPTsetpoint[1]) SCPTsetpoint[0] < SCPTsetpoint[1]
Zero (Offset) Adjustment	nvoRSPVal zero (offset) adjustment (SCPToffset) Added to the calculation result with SCPTsetpoint[0,1] and SCPTgain. Selectable within -163.840...163.835%
Span (Gain) Adjustment	nvoRSPVal span (gain) adjustment (SCPTgain) Gain = Multiplier / 10000 (Divisor is fixed at 10000.), applied to SCPTsetpoint[0,1]. Selectable within 0...32000

3.13 fbYV[0,1]

fbYV[0]

fbYV Network Variables

Input
nviYVVal Output

Source

fbYV Configuration Property

Output Range(SCPTsceneNmbr)

nviYVVal Configuration Property

Lower Range Value (SCPTsetpoint[0])
(-15.000-115.000%)

Upper Range Value (SCPTsetpoint[1])
(-15.000-115.000%)

Zero (Offset) Adjustment (SCPToffset):

Span (Gain) Adjustment
(SCPTgain multiplier; divisor = 10000): (0-32000)

Parameter	Function
nviYVVal	Indicates nviYVVal value in % of the selected range. Read-in values may not match actual field values.
Source	Network variable connected to nviYVVal Bound NV : Other than listed below fbCV[0] : nvoCVOOut fbCV[1] : nvoCVOOut
Output Range	Output range for Output 0 and 1 (SCPTsceneNmbr) 0 : -10.00 to 10.00 V 1 : -5.00 to 5.00 V 2 : -1.00 to 1.00 V 3 : 0.00 to 10.00 V 4 : 0.00 to 5.00 V 5 : 1.00 to 5.00 V 6 : 0.00 to 1.00 V 7 : -0.500 to 0.500 V 8 : 0.000 to 0.500 V
Lower Range Value	nviYVVal lower range voltage in % of the output range (SCPTsetpoint[0]) Selectable within -15.000...115.000%. SCPTsetpoint[0] < SCPTsetpoint[1]
Upper Range Value	nviYVVal upper range voltage in % of the output range (SCPTsetpoint[1]) Selectable within -15.000...115.000%. SCPTsetpoint[0] < SCPTsetpoint[1]
Zero (Offset) Adjustment	nviYVVal zero (offset) adjustment (SCPToffset) Added to the calculation result with SCPTsetpoint[0,1] and SCPTgain. Selectable within -15.000...115.000%
Span (Gain) Adjustment	nviYVVal span (gain) adjustment (SCPTgain) Gain = Multiplier / 10000 (Divisor is fixed at 10000.), applied to SCPTsetpoint[0,1]. Selectable within 0...32000

3.14 fbYS[0,1]

fbYS[0]

fbYS Network Variables

Input
 nviYSVal Output
 Source

nviYSVal Configuration Property

Lower Range Value (SCPTsetpoint[0])
 (-15.000-115.000%)
 Upper Range Value (SCPTsetpoint[1])
 (-15.000-115.000%)
 Zero (Offset) Adjustment (SCPToffset):
 Span (Gain) Adjustment (SCPTgain multiplier, divisor = 10000): (0-32000)

Parameter	Function
nviYSVal	Indicates nviYSVal value in % of the selected range. Read-in values may not match actual field values.
Source	Network variable connected to nviYSVal Bound NV : Other than listed below fbCV[0] : nvoCVOOut fbCV[1] : nvoCVOOut
Lower Range Value	nviYSVal lower range current in % of the output range (SCPTsetpoint[0]) Selectable within -15.000...115.000%. SCPTsetpoint[0] < SCPTsetpoint[1]
Upper Range Value	nviYSVal upper range current in % of the output range (SCPTsetpoint[1]) Selectable within -15.000...115.000%. SCPTsetpoint[0] < SCPTsetpoint[1]
Zero (Offset) Adjustment	nviYSVal zero (offset) adjustment (SCPToffset) Added to the calculation result with SCPTsetpoint[0,1] and SCPTgain. Selectable within -15.000...115.000%
Span (Gain) Adjustment	nviYSVal span (gain) adjustment (SCPTgain) Gain = Multiplier / 10000 (Divisor is fixed at 10000.), applied to SCPTsetpoint[0,1]. Selectable within 0...32000

3.15 fbCV[0...3]

Parameter	Function
nviCVIn	Indicates nviCVIn value. Read-in values may not match actual field values.
(NvType)	Setting Network Variable type for nviCVIn SNVT_lev_percent SNVT_temp SNVT_temp_p SNVT_count_32
Source	Network variable connected to nviCVIn Bound NV : Other than listed below fbX[0] : nvoXVal fbX[1] : nvoXVal fbX[2] : nvoXVal fbX[3] : nvoXVal X = Analog input functional block (e.g. fbSV)
nvoCVOOut	Indicates nvoCVOOut value. Read-in values may not match actual field values.
(NvType)	Setting Network Variable type for nvoCVOOut SNVT_lev_percent SNVT_temp SNVT_temp_p SNVT_count_32
Scaling Setting nviCVIn Value	nviCVIn 0% and 100% input value setting (SCPTsetpoint[0,1]) Upper edit field for 0%; lower edit field for 100% Selectable value/range depends upon the connected fb type.
Scaling Setting nvoCVOOut Value	nvoCVOOut 0% and 100% output value setting (SCPTsetpoint[0,1]) Upper edit field for 0%; lower edit field for 100% Selectable value/range depends upon the connected fb type.

3.16 fbARM[0...3]

fbARM01

fbARM Network Variables

Input	nviARMIn	from Device	Output	nvoARM1	from Device
(Unit)				nvoARM2	from Device
(NvType)	SNVT_count_32			nvoARM3	from Device
Source	Bound NV			nvoARM4	from Device

NviARMIn Configuration Property

Alarm Setpoint (SCPTsetpoint[0-3]) :

nvoARM1 (HH)	10000
nvoARM2 (H)	9000
nvoARM3 (L)	1000
nvoARM4 (LL)	10

Alarm Hysteresis(Deadband)(SCPToffset): 50

Read value from Database Read value from Device Apply To Database Apply To Database And Device

Parameter	Function
nviARMIn	Indicates nviARMIn value. Read-in values may not match actual field values.
(NvType)	Setting Network Variable type for nviARMIn SNVT_lev_percent SNVT_temp SNVT_temp_p SNVT_count_32
Source	Network variable connected to nviARMIn Bound NV : Other than listed below fbX[0] : nvoXVal fbX[1] : nvoXVal fbX[2] : nvoXVal fbX[3] : nvoXVal X = Analog input functional block (e.g. fbSV)
nvoARM	Indicates nvoARM1, nvoARM2, nvoARM3 and nvoARM4 values. Read-in values may not match actual field values.
Alarm Setpoint	Setting threshold values for nvoARM1, nvoARM2, nvoARM3 and nvoARM4 nvoARM1 (HH) : Alarm 1 (HH) setpoint nvoARM2 (H) : Alarm 2 (H) setpoint nvoARM3 (L) : Alarm 3 (L) setpoint nvoARM4 (LL) : Alarm 4 (LL) setpoint nvoARM provides 100.0 1 (ON) when the input is above HH or H setpoint. nvoARM provides 100.0 1 (ON) when the input is below L or LL setpoint.
Alarm Hysteresis (Deadband)	Setting deadband value for nvoARM (SCPToffset)

3.17 fbLED[0]

fbLED

fbLED Network Variables

Input

nviLEDState	from Device
nviLEDIn01	from Device
nviLEDIn02	from Device
nviLEDIn03	from Device
nviLEDIn04	from Device
nviLEDIn05	from Device
nviLEDIn06	from Device
nviLEDIn07	from Device
nviLEDIn08	from Device
nviLEDIn09	from Device
nviLEDIn10	from Device
nviLEDIn11	from Device
nviLEDIn12	from Device
nviLEDIn13	from Device
nviLEDIn14	from Device
nviLEDIn15	from Device
nviLEDIn16	from Device

Read value from Database Read value from Device Apply To Database Apply To Database And Device

Parameter	Function
nviLEDIn01...16	Indicates nviLEDIn01...16 value. Read-in values may not match actual field values.

3.18 fbRR[0,1]

fbRR01

fbRR Network Variables

Input		Output	
nviRROut1	from Device	nvoRRIn1	from Device
nviRROut2	from Device	nvoRRIn2	from Device
nviRROut3	from Device	nvoRRIn3	from Device
nviRROut4	from Device	nvoRRIn4	from Device

Read value from Database Read value from Device Apply To Database Apply To Database And Device

Parameter	Function
nviRROut1...4	Indicates nviRROut1...4 value. Read-in values may not match actual field values.
nvoRRIn1...4	Indicates nvoRRIn1...4 value. Read-in values may not match actual field values.