# NPN TRANSISTOR OUTPUT MODULE

(voltage contact, with short circuit protection; 4 points)

MODEL R8-DC4A2

## **BEFORE USE ....**

Thank you for choosing us. Before use, please check contents of the package you received as outlined below. If you have any problems or questions with the product, please contact our sales office or representatives.

### **■ PACKAGE INCLUDES:**

NPN transistor output module.....(1)

#### ■ MODEL NO.

Confirm Model No. marking on the product to be exactly what you ordered.

#### **■ INSTRUCTION MANUAL**

This manual describes necessary points of caution when you use this product, including installation, connection and basic maintenance procedures.

## **POINTS OF CAUTION**

### **■ CONFORMITY WITH EU DIRECTIVES**

- The equipment must be mounted inside a panel.
- The actual installation environments such as panel configurations, connected devices and connected wires may affect the protection level of this unit when it is integrated in a panel system. The user may have to review the CE requirements in regard to the whole system and employ additional protective measures to ensure CE conformity.

## **■ GENERAL PRECAUTIONS**

- Before you remove or mount the unit, turn off the power supply and output signal for safety.
- Switches on the side of the module can be set for maintenance only while the power supply is off. Do not access them while the power is supplied.

## **■** ENVIRONMENT

- Indoor use.
- When heavy dust or metal particles are present in the air, install the unit inside proper housing with sufficient ventilation.
- Do not install the unit where it is subjected to continuous vibration. Do not subject the unit to physical impact.
- Environmental temperature must be within -10 to +55°C (14 to 131°F) with relative humidity within 30 to 90% RH in order to ensure adequate life span and operation.

### **■** WIRING

- Do not install cables close to noise sources (relay drive cable, high frequency line, etc.).
- Do not bind these cables together with those in which noises are present. Do not install them in the same duct.


### ■AND ....

The unit is designed to function as soon as power is supplied, however, a warm up for 10 minutes is required for satisfying complete performance described in the data sheet.

## INSTALLATION


### ■ HOW TO MOUNT THE MODULE ON DIN RAIL

• I/O Module




Confirm that the locking clamps of the I/O module are set. Insert the module in parallel to the next one while aligning the grooves of both modules (A & B in the above figure).


Maintain it perpendicularly to the rail.



More I/O modules can be added in the same manner.




### • Protective Cover




The protective cover is to be attached over the connected I/O module at the right end.

Align the hooks on the cover with the grooves of the module and slide it straight until the hooks are latched.





When removing the cover, pull it out while squeezing the hooks inward.




### ■ HOW TO UNMOUNT THE MODULE FROM DIN RAIL

Release the locking clamps and pull out straight the module.





## • Removing an intermediate module




## Caution!

- 1) Be careful not to hurt your hand by pointed edges of the internal bus connector.
- I/O modules cannot hold tightly on the DIN rail by themselves without power/network module.

Secure them to the position if necessary by using DIN rail end plates.

## **COMPONENT IDENTIFICATION**



### **■ INDICATOR LED**

LED	OPERATION	FUNCTION
Status OFF		Stopping
	Green ON	Valid host communication
	Green Blinking	Reading/writing configura-
		tion
	Red ON	Setting error
	Red Blinking	Parameter error
Output	OFF	OFF
Status	Green ON	ON

## **■ OUTPUT CONNECTOR ASSIGNMENT**



PIN No.	ID	FUNCTION
1	24V	Excitation supply 24 V
2	NC	No connection
3	NC	No connection
4	DO	Discrete output

### **■ PC CONFIGURATOR**

The following parameters can be set with using PC Configurator Software (model: R8CFG):

- Output at the startup
- Output at the loss of communication
- Common setting (loss of internal bus communication detection time)

Turn SW4-8 ON to allow programming by the PC Configurator via the Power/Network Module.

Refer to the users manual for the R8CFG for detailed operation of the software program.

### **■ MODULE ADDRESS**

The left switch determines the tenth place digit, while the right switch does the ones place digit of the address. Address is selected between  $0\ \text{to}\ 31.$ 

(Factory setting: 0)



### **■ OPERATING MODE**

\*Factory setting

### Output at The Loss of Communication

OUTPUT AT THE LOSS OF COMMUNICATION	SW4-7
Output Hold (*)	OFF
(last data correctly received is hold)	
Stop output (Output fixed at OFF)	ON

## Configuration Mode

CONFIGURATION MODE	SW4-8
DIP switch setting (*)	OFF
PC Configurator and communication	ON

## • Terminator DIP SW


With	ON	
Without (*)	OFF	
TERMINATOR SW	SW3	


Note: Be sure to set unused SW4-1 through 4-6 to OFF.

## **TERMINAL CONNECTIONS**


Connect the unit as in the diagram below.

## **■ EXTERNAL DIMENSIONS** unit: mm (inch)





## **■ CONNECTION DIAGRAM**



# **WIRING INSTRUCTIONS**

## **■** e-CON connector

Unit side connector: XN2D-1474-S002 (Omron) Recommended cable side connector: XN2A-1470 (Omron)\*1 Applicable wire size:  $0.08 - 0.5 \text{ mm}^2 \text{ (AWG28} - 20)$ Outer sheath diameter: max. 1.5 dia

\*1. The cable side connector is not included in the package. Refer to the specifications of the product.