## INSTRUCTION MANUAL

# DC VOLTAGE INPUT MODULE

## (8 points, isolated, tension clamp terminal block)

## **BEFORE USE ....**

Thank you for choosing us. Before use, please check contents of the package you received as outlined below. If you have any problems or questions with the product, please contact our sales office or representatives.

## ■ PACKAGE INCLUDES:

## MODEL NO.

Confirm Model No. marking on the product to be exactly what you ordered.

## ■ INSTRUCTION MANUAL

This manual describes necessary points of caution when you use this product, including installation, connection and basic maintenance procedures.

## **POINTS OF CAUTION**

## ■ CAUTION

• If the equipment is used in a manner not specified by this manual, the protection provided by the equipment may be impaired.

### CONFORMITY WITH UL APPROVAL

- This equipment is suitable for use in Installation Category II and in a Pollution Degree 2 environment.
- Altitude up to 2000 meters.
- Install inside an industrial control panel or equivalent for UL.
- Make sure the used Power/Network module is the UL approval that is appropriately evaluated with this equipment.

## ■ CONFORMITY WITH EU DIRECTIVES

- The equipment must be mounted inside a panel.
- The actual installation environments such as panel configurations, connected devices, connected wires, may affect the protection level of this unit when it is integrated in a panel system. The user may have to review the CE requirements in regard to the whole system and employ additional protective measures\* to ensure the CE conformity.
  - \* For example, installation of noise filters and clamp filters for the power source, input and output connected to the unit, etc.

### ■ POWER REQUIRMENTS

• The equipment receives power through the internal circuit and confirms its operational range as indicated below: Internal Power: 5V DC,  $\leq$  200mA

## ■ GENERAL PRECAUTIONS

• Before you remove or mount the unit, turn off the power supply and input signal for safety.

MODEL

**R8-SVT8** 

- Do not touch the connector while the power is supplied. Static electricity may cause a malfunction.
- Switches on the side of the module can be set for maintenance only while the power supply is off. Do not access them while the power is supplied.

### ■ ENVIRONMENT

#### • Indoor use.

- When heavy dust or metal particles are present in the air, install the unit inside proper housing with sufficient ventilation.
- Do not install the unit where it is subjected to continuous vibration. Do not subject the unit to physical impact.
- Environmental temperature must be within -10 to  $+55^{\circ}$ C (14 to  $131^{\circ}$ F) with relative humidity within 30 to 90% RH in order to ensure adequate life span and operation.

#### ■ WIRING

- Do not install cables close to noise sources (relay drive cable, high frequency line, etc.).
- Do not bind these cables together with those in which noises are present. Do not install them in the same duct.


#### ■ AND ....

• The unit is designed to function as soon as power is supplied, however, a warm up for 10 minutes is required for satisfying complete performance described in the data sheet.


# INSTALLATION

HOW TO MOUNT THE MODULE ON DIN RAIL


• I/O Module




Confirm that the locking clamps of the I/O module are set. Insert the module in parallel to the next one while aligning the grooves of both modules (A & B in the above figure). Maintain it perpendicularly to the rail.




More I/O modules can be added in the same manner.






The protective cover is to be attached over the connected  $\ensuremath{\mathsf{I/O}}$  module at the right end.

Align the hooks on the cover with the grooves of the module and slide it straight until the hooks are latched.





When removing the cover, pull it out while squeezing the hooks inward.




#### ■ HOW TO UNMOUNT THE MODULE ON DIN RAIL


Release the locking clamps and pull out straight the module.





Removing an intermediate module






#### Caution !

- 1) Be careful not to hurt your hand by pointed edges of the internal bus connector.
- 2) I/O modules cannot hold tightly on the DIN rail by themselves without power/network module.

Secure them to the position if necessary by using DIN rail end plates.

# **COMPONENT IDENTIFICATION**



## ■ INDICATOR LED

ID	OPERATION	FUNCTION
Status	OFF	Stopping
	Green ON	Valid host communication
	Green Blinking	Reading/writing configuration
	Red ON	Setting error
	Red Blinking	Parameter error
Input	OFF	Input data in the range
Status	Red Blinking	Input data out of range

## ■ INPUT CONNECTOR ASSIGNMENT

	PIN No.	ID	FUNCTION		
	1	In1	Input 1 (+)		
	2	Ini	Input 1 (–)		
	3		Input 2 (+)		
	4	In2	Input 2 (–)		
·	5	Tre 9	Input 3 (+)		
	6	In3	Input 3 (–)		
	7	In4	Input 4 (+)		
	8		Input 4 (–)		
	9	T	Input 5 (+)		
	10	In5	Input 5 (–)		
	11	In6	Input 6 (+)		
	12		Input 6 (–)		
	13	In7	Input 7 (+)		
	14		Input 7 (–)		
	15	TO	Input 8 (+)		
	16	In8	Input 8 (–)		

## ■ MODULE ADDRESS: SW1

SW1-1 through 1-4 determine the tenth place digit, while SW1-5 through 1-8 do the ones place digit of the module address.

Address is selected between 0 to 28.

(Factory setting: 0)

	SW1				
MODULE ADDRESS	×10	1	2	3	4
	×1	5	6	7	8
0		OFF	OFF	OFF	OFF
1		OFF	OFF	OFF	ON
2		OFF	OFF	ON	OFF
3		OFF	OFF	ON	ON
4		OFF	ON	OFF	OFF
5		OFF	ON	OFF	ON
6		OFF	ON	ON	OFF
7		OFF	ON	ON	ON
8		ON	OFF	OFF	OFF
9		ON	OFF	OFF	ON

#### ■ OPERATING MODE

(\*) Factory setting

#### • Input Range: SW2-1, 2

Same setting for all channels. Use PC Configurator to set independent ranges per channel.

INPUT RANGE	SW2		
(Signal Level)	1	2	
-10 - +10V DC (*)	OFF	OFF	
0 - 10V DC	ON	OFF	
0 - 5V DC	OFF	ON	
1 - 5V DC	ON	ON	

## • Terminator DIP SW: SW2-6

TERMINATOR DIP SW	SW2-6
Without (*)	OFF
With	ON

#### Configuration Mode: SW2-8

CONFIGURATION MODE	SW2-8		
DIP switch setting (*)	OFF		
PC Configurator and communication	ON		
Note: Be sure to set unused SW2-3 through 2-5 and 2-7 to OFF.			

MG CO., LTD. www.mgco.jp 5-2-55 Minamitsumori, Nishinari-ku, Osaka 557-0063 JAPAN

# **PC CONFIGURATOR**

The following parameter items can be configured with PC Configurator Software (model: R8CFG). Refer to the users manual of the software for detailed operations.

## CHANNEL INDIVIDUAL SETTING

PARAMETER	SETTING RANGE	DEFAULT SETTING
Input Range	-10 to +10 (V DC)	-10 to +10 (V DC)
Zero input value	-10.00 to +10.00 (V)	-10.00 (V)
Span input value	-10.00 to +10.00 (V)	10.00 (V)
Fine zero adjustment	-320.00 to +320.00 (%)	0.00 (%)
Fine gain adjustment	-3.2000 to +3.2000	1.0000
Scaled range Zero	-32000 to +32000	0
Scaled range Span	-32000 to +32000	10000

## CHANNEL BATCH SETTING


PARAMETER	SETTING RANGE	DEFAULT SETTING
Loss of internal bus communication detection time	0.0 to 99.9 (sec.)	1.0 (sec.)
Input moving average	Disable / Enable (8 times)	Disable
Configuration mode	DIP switch (OFF),	DIP switch (OFF)
	PC (ON)	

Note: Turn SW2-8 ON to allow programming by the PC Configurator via the Power/Network Module.


## **TERMINAL CONNECTIONS**

Connect the unit as in the diagram below.

### ■ EXTERNAL DIMENSIONS unit: mm (inch)



## ■ CONNECTION DIAGRAM



## WIRING INSTRUCTIONS

■ TENSION CLAMP TERMINAL BLOCK Unit side connector: MC1,5/16-GF-3,5 (Phoenix Contact) Cable side connector: FMC1,5/16-STF-3,5 (Phoenix Contact) Applicable wire size:  $0.2 - 1.5 \text{ mm}^2 (AWG24 - 15)$ Stripped length: 10 mm **Recommended solderless terminal** • AI0.25-10YE 0.25 mm<sup>2</sup> (AWG23) (Phoenix Contact) • AI0,34-10TQ 0.34 mm<sup>2</sup> (AWG22) (Phoenix Contact) • AI0,5-10WH 0.5 mm<sup>2</sup> (AWG20) (Phoenix Contact) • AI0,75-10GY 0.75 mm<sup>2</sup> (AWG18) (Phoenix Contact) • A1-10  $1.0 \text{ mm}^2$ (AWG17) (Phoenix Contact)

 $1.5 \text{ mm}^2$ 

- A1,5-10
- (AWG15) (Phoenix Contact)

MG CO., LTD. www.mgco.jp 5-2-55 Minamitsumori, Nishinari-ku, Osaka 557-0063 JAPAN