
# Lightning Surge Protectors for Electronics Equipment M-RESTER

# LIGHTNING SURGE PROTECTOR FOR POWER SUPPLY USE

(2 A, 250 V AC / 350 V DC; rack mounted)

#### **Functions & Features**

- Designed specifically for AC/DC power supplies up to
- 2 amps
- Rack-mounted
- Two channels in one housing



# **MODEL: MGA-200**

#### **ORDERING INFORMATION**

Code number: MGA-200

### **GENERAL SPECIFICATIONS**

Construction: Rack-mounted; terminal access via screw terminals at the front; terminal cover provided Connection: M3.5 screw terminals (torque 0.8 N·m) Screw terminal: Nickel-plated steel Housing material: Flame-resistant resin (black) Monitor lamp: Red LED turns on when the power is supplied.

### INSTALLATION


Operating temperature: -5 to +55°C (23 to 131°F) Operating humidity: 30 to 90 %RH (non-condensing) Mounting: Rack-mounted; Standard Rack Mounting Frame BX-16G available Weight: 200 g (0.44 lb)

### PERFORMANCE


Discharge voltage (peak voltage) Line to line: 410 V min. Line to ground: 410 V min. Maximum surge voltage Line to line: 800 V max. Line to ground: 800 V max. (The maximum voltage that could pass through M-RESTER. Protected equipment must be able to withstand this voltage for very short time period.) **Response time**:  $\leq 0.1 \mu$ sec. **Leakage current** Line to line:  $\leq 2 \text{ mA at } 300 \text{ V DC}$ Line to ground:  $\leq 1 \text{ mA at } 300 \text{ V DC}$  **Max. discharge current (Imax)**: 1000 A (8/ 20 µsec.) **Max. load current**: 2 A **Rated line voltage**: 250 V AC, 350 V DC

#### **CONNECTION EXAMPLES**

Connection example with Ch.1




### GROUNDING



A crossover wire between M-RESTER ground and ground or metallic


housing of equipment is required for protection. If the protected equipment has no ground terminal, ground the M-RESTER only.

### **EXTERNAL DIMENSIONS & TERMINAL ASSIGNMENT unit: mm [inch]**




### MOUNTING REQUIREMENTS unit: mm [inch]

■ ANGLE BRACKET



# SCHEMATIC CIRCUITRY



Make sure to connect a DC power source in the proper polarity in order to turn the LED on.



Specifications are subject to change without notice.