

ORDERING INFORMATION

MODEL : JAPD2

PLEASE FILL IN THIS SECTION



Model _____

Company _____

Name _____

P/O No. _____

FACTORY USE ONLY



Job No. _____

Ser No. _____

Sales _____

Approved by (Sales office) _____

Issued by (Sales office) _____

Specify the items you want to change. Standard setting will be used if not specified.

SOFTWARE SETTING

Modifiable with Programming Unit

ITEM	SET VALUE	STANDARD	COMMENTS
OUTPUT ZERO FREQ. ≥0 Hz, < Span Freq.	Hz	0 kHz	Specify the output frequency corresponding to the 0 % input. Settable digit number is 5 including decimal point.
OUTPUT SPAN FREQ. 20 mHz – 20 kHz (20 mHz – 20 Hz for output code R)	Hz	1 kHz (10 Hz for output code R)	Specify the output frequency, which is greater than output zero frequency, corresponding to the 100 % input. Settable digit number is 5 including decimal point.
ALARM OPERATION MODE	<input type="checkbox"/> No alarm <input type="checkbox"/> Upper alarm <input type="checkbox"/> Lower alarm	No alarm	When specifying upper and lower alarm, specify 1 and 2 shown below.
1.ALARM SETPOINT -5.00 – 105.00	%	100.00 %	Specify when alarm output is required.
2.ALARM HYSTERESIS 0.00 – 20.00	%	1.00 %	Deadband. Specify when alarm output is required.
POWER ON-DELAY TIME 2.0 – 1000.0	sec.	3 sec.	Alarm delay at the startup. (accuracy: ±2 sec.)

* Frequency range is selected by us adequately to the zero and span.