

# ORDERING INFORMATION

# MODEL : AS4LC

## PLEASE FILL IN THIS SECTION



Model
Company
Name
P/O No.

## FACTORY USE ONLY



Job No.	Approved by (Sales office)
Ser No.	Issued by (Sales office)
Sales	Approved by (Factory)
	Set by (Factory)

**Specify the items you want to change.  
Default setting will be used if not specified.**

Ser No. \_\_\_\_\_

DEFAULT shows values in case of nothing specified.

### ■ SOFTWARE SETTING

ITEM	DATA	CONTENTS	DEFAULT VALUE	SET VALUE	Factory internal check
L1	-1999 – 9999* <sub>1</sub>	L1 alarm setpoint in engineering unit	Quad: 20.0    Dual: 20.0	L1 :	<input type="checkbox"/>
L2	-1999 – 9999* <sub>1</sub>	L2 alarm setpoint in engineering unit	Quad: 30.0    Dual: 80.0	L2 :	
L3	-1999 – 9999* <sub>1</sub>	L3 alarm setpoint in engineering unit * <sub>2</sub>	Quad: 70.0	L3 :	
L4	-1999 – 9999* <sub>1</sub>	L4 alarm setpoint in engineering unit * <sub>2</sub>	Quad: 80.0	L4 :	
05	0.1 – 12.0	Excitation voltage (V)	1.0		<input type="checkbox"/>
06	0.010 – 3.000 0.010 – 9.999 0.10 – 30.00	Sensor sensitivity    S1 : 0.0 – 3.0mV/V S2 : 0.0 – 10.0mV/V S3 : 0.0 – 30.0mV/V Used when adjusting the sensor sensitivity by its rating value.	S1: 3.000 S2: 9.999 S3: 30.00		<input type="checkbox"/>
14	-1999 – 9999	Display range scaling 0% of the range. ITEM14 < ITEM15	0.0		<input type="checkbox"/>
15	-1999 – 9999	Display range scaling 100% of the range. ITEM14 < ITEM15	100.0		<input type="checkbox"/>
16	0, 1, 2, 3	Decimal point position (Specify number of digits) 0 : ____ 1 : ____. 2 : ____. 3 : ____.	1		<input type="checkbox"/>
17	0, 1, 2, 3, 4	Moving average (sampling cycle: 200 msec.) 0: No, 1: 4 samples, 2: 8 samples, 3: 16 samples, 4: 32 samples	0		<input type="checkbox"/>
18	0, 1, 2, 3	Contact input function 0: Tare adjustment 1: Peak hold 2: Valley hold 3: Sample hold	0		<input type="checkbox"/>
19	0, 1 – 60	Power-saving mode 0: Continuous display after the last access* <sub>3</sub> 1 – 60: Time before display turned off (minutes)	10		<input type="checkbox"/>
20	10 – 99	PowerON-delay time (seconds)	10		<input type="checkbox"/>
21	0 – 99	Alarm ON-delay time (seconds)	0		<input type="checkbox"/>
22	0, 1	L1 trip operation (0: Lo, 1: Hi)	Quad: 0    Dual: 0	22 :	<input type="checkbox"/>
23	0, 1	L2 trip operation (0: Lo, 1: Hi)	Quad: 0    Dual: 1	23 :	
24	0, 1	L3 trip operation (0: Lo, 1: Hi) * <sub>2</sub>	Quad: 1	24 :	
25	0, 1	L4 trip operation (0: Lo, 1: Hi) * <sub>2</sub>	Quad: 1	25 :	
26	0, 1	L1 coil at alarm (0: Energized, 1: De-energized)	0	26 :	<input type="checkbox"/>
27	0, 1	L2 coil at alarm (0: Energized, 1: De-energized)	0	27 :	
28	0, 1	L3 coil at alarm (0: Energized, 1: De-energized) * <sub>2</sub>	0	28 :	
29	0, 1	L4 coil at alarm (0: Energized, 1: De-energized) * <sub>2</sub>	0	29 :	

ITEM	DATA	CONTENTS	DEFAULT VALUE	SET VALUE	Factory internal check
30	1 – 9999	L1 hysteresis (deadband) in engineering unit	1.0	30 :	□
31	1 – 9999	L2 hysteresis (deadband) in engineering unit	1.0	31 :	
32	1 – 9999	L3 hysteresis (deadband) in engineering unit *2	1.0	32 :	
33	1 – 9999	L4 hysteresis (deadband) in engineering unit *2	1.0	33 :	

\*1. Selectable within the display scaling range

\*2. Quad alarm trip type only

\*3. OFF when power is on. After power is turned on, pressing any key enables to turn on continuously.