

ORDERING INFORMATION

MODEL : AS4M

PLEASE FILL IN THIS SECTION



| |
|---------|
| Model |
| Company |
| Name |
| P/O No. |

FACTORY USE ONLY



| | |
|---------|-------------------------------|
| Job No. | Approved by (Sales office) |
| Ser No. | Issued by (Sales office) |
| Sales | Approved by (Factory) |
| | Set by (Factory) |

**Specify the items you want to change.
Default setting will be used if not specified.**

Ser No. _____

DEFAULT shows values in case of nothing specified.

■ SOFTWARE SETTING

| ITEM | DATA | CONTENTS | DEFAULT VALUE | SET VALUE | Factory internal check |
|---------|----------------|--|-----------------------|-----------|--------------------------|
| L1 | -1999 – 9999*1 | L1 alarm setpoint in engineering unit | Quad: 20.0 Dual: 20.0 | L1 : | <input type="checkbox"/> |
| L2 | -1999 – 9999*1 | L2 alarm setpoint in engineering unit | Quad: 30.0 Dual: 80.0 | L2 : | |
| L3 | -1999 – 9999*1 | L3 alarm setpoint in engineering unit *2 | Quad: 70.0 | L3 : | |
| L4 | -1999 – 9999*1 | L4 alarm setpoint in engineering unit *2 | Quad: 80.0 | L4 : | |
| 07 | -1999 – 9999 | Display range scaling 0% of the range set in ITEM 27/28. ITEM 07 < ITEM 08 | 0.0 | | <input type="checkbox"/> |
| 08 | -1999 – 9999 | Display range scaling 100% of the range set in ITEM 27/28. ITEM 07 < ITEM 08 | 100.0 | | <input type="checkbox"/> |
| 09 | 0, 1, 2, 3 | Decimal point position (Specify number of digits) 0 : _ _ _ _ 1 : _ _ . _ 2 : _ . _ _ 3 : _ . _ _ _ | 1 | | <input type="checkbox"/> |
| 10 | 0 – 99 | Power ON-delay time (seconds) | 5 | | <input type="checkbox"/> |
| 11 | 0 – 999 | Alarm ON-delay time (seconds) | 0 | | <input type="checkbox"/> |
| 12 | 0, 1, 2, 3, 4 | Moving average (sampling cycle: 100 msec.) 0: No, 1: 4 samples, 2: 8 samples, 3: 16 samples, 4: 32 samples | 0 | | <input type="checkbox"/> |
| 13 | 0, 1 | L1 trip operation (0: Lo, 1: Hi) | Quad: 0 Dual: 0 | 13 : | <input type="checkbox"/> |
| 14 | 0, 1 | L2 trip operation (0: Lo, 1: Hi) | Quad: 0 Dual: 1 | 14 : | |
| 15 | 0, 1 | L3 trip operation (0: Lo, 1: Hi) *2 | Quad: 1 | 15 : | |
| 16 | 0, 1 | L4 trip operation (0: Lo, 1: Hi) *2 | Quad: 1 | 16 : | |
| -1 7 | -1, 0, 1 – 60 | Power-saving mode -1 : Continuous display upon startup 0 : Continuous display after the last access 1 – 60 : Time before display turned off (minutes) | 10 | | <input type="checkbox"/> |
| 18 | 0, 1 | L1 coil at alarm (0: Energized, 1: De-energized) | 0 | 18 : | <input type="checkbox"/> |
| 19 | 0, 1 | L2 coil at alarm (0: Energized, 1: De-energized) | 0 | 19 : | |
| 20 | 0, 1 | L3 coil at alarm (0: Energized, 1: De-energized) *2 | 0 | 20 : | |
| 21 | 0, 1 | L4 coil at alarm (0: Energized, 1: De-energized) *2 | 0 | 21 : | |
| 23 | 1 – 9999 | L1 hysteresis (deadband) in engineering unit | 1.0 | 23 : | <input type="checkbox"/> |
| 24 | 1 – 9999 | L2 hysteresis (deadband) in engineering unit | 1.0 | 24 : | |
| 25 | 1 – 9999 | L3 hysteresis (deadband) in engineering unit *2 | 1.0 | 25 : | |
| 26 | 1 – 9999 | L4 hysteresis (deadband) in engineering unit *2 | 1.0 | 26 : | |
| 27 | 0.0 – 100.0 | 0% input (%) | 0.0% | | <input type="checkbox"/> |
| 28 | 0.0 – 100.0 | 100% input (%) | 100.0% | | <input type="checkbox"/> |
| 29 | 0, 1 | Latching control (0: Disabled, 1: Enabled) Selecting "0" resets latching relays. Turning power supply off also resets them. | 0 | | <input type="checkbox"/> |

*1. Selectable within the display scaling range

*2. Quad alarm trip type only