

# ORDERING INFORMATION

# Model : MXLCF

PLEASE FILL IN THIS SECTION		FACTORY USE ONLY		
↓ ↓ ↓		↓ ↓ ↓ ↓ ↓		
Model		Job No.		Approved by (Sales office)
Company		Ser No.	—	Issued by (Sales office)
Name		Sales		Approved by (Factory)
P/O No.				Set by (Factory)

Specify the items you want to change. Default setting will be used if not specified.

## SOFTWARE SETTING

ITEM	DATA	CONTENTS	DEFAULT VALUE	SPECIFY YOUR PREFERENCE	Factory Internal check
05	0.1 – 12.0	Excitation voltage (V)	1.0		<input type="checkbox"/>
06	0010 – 9999 0.010 – 3.000 0.010 – 9.999 0.10 – 30.00	Sensor sensitivity S1 : 0.0 - 1.0mV/V S2 : 0.0 – 3.0mV/V S3 : 0.0 – 10.0mV/V S4 : 0.0 – 30.0mV/V Used when adjusting the sensor sensitivity by its rating value.	S1 : 0.9999mV/V S2 : 3.000mV/V S3 : 9.999mV/V S4 : 30.00mV/V		<input type="checkbox"/>
14	-9999 – 9999	Display range scaling 0% *1	0.0		<input type="checkbox"/>
15	-9999 – 9999	Display range scaling 100% *1	100.0		<input type="checkbox"/>
16	0, 1, 2, 3	Decimal point position 0 : _ _ _ _ 1 : _ _ . _ 2 : _ . _ _ 3 : _ . _ _ _	1		<input type="checkbox"/>
17	0, 1, 2, 3, 4, 5	Moving average 0: No 1: 4 samples 2: 8 samples 3: 16 samples 4: 32 samples 5: 64 samples	1		<input type="checkbox"/>
18	0, 1, 2, 3	Contact input function 0 : Tare adjustment 1 : Peak hold 2 : Valley hold 3 : Sample hold	0		<input type="checkbox"/>
20	0, 1 – 60	Power-saving mode 0 : Continuous display 1 – 60 : Time before display turned off (minutes)	10		<input type="checkbox"/>
21	-1.00 – 1.00 -10.0 – 10.0 0.0 – 20.0	Output code V1 0% output voltage (V) Output code V2 0% output voltage (V) Output code Z1 0% output current (mA) ITEM 21 < ITEM 22.	-1.00 -10.0 4.0		<input type="checkbox"/>
22	-1.00 – 1.00 -10.0 – 10.0 0.0 – 20.0	Output code V1 100% output voltage (V) Output code V2 100% output voltage (V) Output code Z1 100% output current (mA) ITEM 21 < ITEM 22.	1.00 10.0 20.0		<input type="checkbox"/>

\*1 : Of the range set in ITEM 06/07/08. ITEM 14 < ITEM 15.

Note: This product is calibrated as indicated on the above table, however, please calibrate the unit in accordance with the actual installation.