

ORDERING INFORMATION

Model : MXAB

PLEASE FILL IN THIS SECTION



Model
Company
Name
P/O No.

FACTORY USE ONLY



Job No	Approved by (Sales office)
Ser No.	Issued by (Sales office)
Sales	Approved by (Factory)
	Set by (Factory)

Specify the items you want to change. Default setting will be used if not specified.
DEFAULT shows values in case of nothing specified.

Ser No. _____

SOFTWARE SETTING

ITEM	DATA	CONTENTS	DEFAULT VALUE	SPECIFY YOUR PREFERENCE	Factory Internal check
08	-9999 – 9999	Display range scaling 0% ^{*1}	0.0		<input type="checkbox"/>
09	-9999 – 9999	Display range scaling 100% ^{*1}	100.0		<input type="checkbox"/>
10	0, 1, 2, 3	Decimal point position 0 : ____ 1 : ____. 2 : ____. 3 : ____.	1		<input type="checkbox"/>
11	0, 1, 2, 3, 4, 5	Moving average (sampling cycle: 10 msec.) 0: No 1: 5 samples 2: 8 samples 3: 12 samples 4: 20 samples 5: 36 samples	1		<input type="checkbox"/>
12	0 – 12	Response time 12 : Approx. 100 sec. (0 – 90%) Decreasing DATA by 1 increment cuts the response time by half.	1		<input type="checkbox"/>
13	0, 1	MANUAL control mode 0 : Trace back mode; Goes back the preset 'trace-back time' 1 : Fixed value mode; Holds the preset 'initial value in MANUAL mode'	0		<input type="checkbox"/>
14	-15.0 – 115.0	Initial value in MANUAL mode (Specify it when "1: Fixed value mode; Holds the preset 'Initial value in MANUAL mode'" is selected in ITEM 13.)	-15.0		<input type="checkbox"/>
15	0 – 20	Trace-back time (sec.)	0		<input type="checkbox"/>
16	0, 1 – 100	Transition speed (%/sec.) (For tracking the new input when switched from MANUAL to AUTO mode) 0 : CAS operation is restored without going through the transition response when MAN command is OFF.	0		<input type="checkbox"/>
17	0, 1	Output stored at the loss of power 0 : Disable 1 : Enable	1		<input type="checkbox"/>
18	-15.0 – 115.0	Initial value at start-up (Specify it "when 0: Disable" is selected in ITEM 17.)	-15.0		<input type="checkbox"/>
19	1 – 999	UP-DOWN key response time (0 – 100%, sec.)	20		<input type="checkbox"/>
20	0, 1	Transition response time 0 : Disable; Response is determined only by UP/DOWN key response time setting. 1 : Enable; Response increases gradually from 0% to the UP-DOWN key response time setting.	0		<input type="checkbox"/>
21	0, 1 – 60	Power-saving mode 0 : Continuous display 1 – 60 : Time before display turned off (minutes)	10		<input type="checkbox"/>
24	0, 1	DOWN input logic 0 : True at LOW or Shortcircuit 1 : True at HIGH or Opencircuit	0 ^{*2}		<input type="checkbox"/>
25	0, 1	UP input logic 0 : True at LOW or Shortcircuit 1 : True at HIGH or Opencircuit	0 ^{*2}		<input type="checkbox"/>
26	0 – 3	STOP input logic 0 : AUTO mode at LOW or Shortcircuit (Input updating halted at STOP) 1 : AUTO mode at HIGH or Opencircuit (Input updating halted at STOP) 2 : AUTO mode at LOW or Shortcircuit 3 : AUTO mode at HIGH or Opencircuit	2 ^{*2}		<input type="checkbox"/>

ITEM	DATA	CONTENTS	DEFAULT VALUE	SPECIFY YOUR PREFERENCE	Factory Internal check
27	S1: -1.00 – 1.00 S2: -10.0 – 10.0 S3: -30.0 – 30.0	Input code S1 Input code S2 Input code S3	0% input voltage (V) ^{*3} 0% input voltage (V) ^{*3} 0% input voltage (V) ^{*3}	S1: -1.00 S2: -10.0 S3: -30.0	<input type="checkbox"/>
28	S1: -1.00 – 1.00 S2: -10.0 – 10.0 S3: -30.0 – 30.0	Input code S1 Input code S2 Input code S3	100% input voltage (V) ^{*3} 100% input voltage (V) ^{*3} 100% input voltage (V) ^{*3}	S1: 1.00 S2: 10.0 S3: 30.0	<input type="checkbox"/>
29	V1: -1.00 – 1.00 V2: -10.0 – 10.0 Z1: 0.0 – 20.0	Output code V1 Output code V2 Output code Z1	0% output voltage (V) ^{*4} 0% output voltage (V) ^{*4} 0% output current (mA)	V1: -1.00 V2: -10.0 Z1: 4.0	<input type="checkbox"/>
30	V1: -1.00 – 1.00 V2: -10.0 – 10.0 Z1: 0.0 – 20.0	Output code V1 Output code V2 Output code Z1	100% output voltage (V) ^{*4} 100% output voltage (V) ^{*4} 100% output current (mA)	V1: 1.00 V2: 10.0 Z1: 20.0	<input type="checkbox"/>
31	-15.0 – 114.9	Lower output limit	-15.0		<input type="checkbox"/>
32	-14.9 – 115.0	Upper output limit	115.0		<input type="checkbox"/>

*1 : Of the range set in ITEM 27/28. ITEM 08 < ITEM 09.

*2 : Use the default setting when combining with the ST/STL.

*3 : ITEM 27 < ITEM 28.

*4 : ITEM 29 < ITEM 30.