

ORDERING INFORMATION

Model : M5XSES

PLEASE FILL IN THIS SECTION



Model
Company
Name
P/O No.

FACTORY USE ONLY



Job No.	Approved by (Sales office)
Ser No.	Issued by (Sales office)
Sales Rep.	Approved by (Factory)
	Issued by (Factory)
	Ser No.

Specify the items you want to change. Default setting will be used if not specified.

INPUT SETTING

ITEM		SET VALUE	DEFAULT VALUE	COMMENTS	FACTORY INTERNAL CHECK
Input 1	Input range	<input type="checkbox"/> 0 to 50 mA DC <input type="checkbox"/> -1000 to +1000 mV DC <input type="checkbox"/> -10 to +10 V DC	0 to 50 mA DC		<input type="checkbox"/>
	0 % input setting		4.0000 mA 0.00 mV 0.0000 V	Specify within settable range in the table 1.	<input type="checkbox"/>
	100 % input setting		20.0000 mA 1000.00 mV 10.0000 V		
	Low-end cut point		0.0000 %	Specify within the range of 0.0000 to 99.9999.	<input type="checkbox"/>
	Input lower limit		-2.0000 %	Specify within the range of -2.0000 to 101.0000.	<input type="checkbox"/>
	Input upper limit		102.0000 %	Specify within the range of -1.0000 to 102.0000.	<input type="checkbox"/>
Input 2	Input range	<input type="checkbox"/> 0 to 50 mA DC <input type="checkbox"/> -1000 to +1000 mV DC <input type="checkbox"/> -10 to +10 V DC	0 to 50 mA DC		<input type="checkbox"/>
	0 % input setting		4.0000 mA 0.00 mV 0.0000 V	Specify within settable range in the table 1.	<input type="checkbox"/>
	100 % input setting		20.0000 mA 1000.00 mV 10.0000 V		
	Low-end cut point		0.0000 %	Specify within the range of 0.0000 to 99.9999.	<input type="checkbox"/>
	Input lower limit		-2.0000 %	Specify within the range of -2.0000 to 101.0000.	<input type="checkbox"/>
	Input upper limit		102.0000 %	Specify within the range of -1.0000 to 102.0000.	<input type="checkbox"/>
Filter time constant*1			0.0 sec.	Specify the range between 0.0 and 30.0 sec.	<input type="checkbox"/>

*1. Filter time constant

Set filter time constant of the first order lag filter. The first order lag filter is available with setting time.

When '0' is set to this parameter, the first order lag filter is not available (Response time: ≤ 0.5 sec. (0 - 90 %)).

The first order lag filter is equivalent to general CR filter.

The setting time constant is the time to follow until about 63 %, when input varies from 0 % to 100 %.

■ COMPUTING SETTING

ITEM	SET VALUE	DEFAULT VALUE	COMMENTS	FACTORY INTERNAL CHECK
Select input	<input type="checkbox"/> High selector <input type="checkbox"/> Low selector	High selector	High selector $X0 = X1$ with $X1 \geq X2$ $X0 = X2$ with $X1 < X2$ Low selector $X0 = X2$ with $X1 \geq X2$ $X0 = X1$ with $X1 < X2$	<input type="checkbox"/>

■ OUTPUT SETTING

ITEM	SET VALUE	DEFAULT VALUE	COMMENTS	FACTORY INTERNAL CHECK
Output range	<input type="checkbox"/> 0 to 20 mA DC <input type="checkbox"/> -5 to +5 V DC <input type="checkbox"/> -10 to +10 V DC	0 to 20 mA DC		<input type="checkbox"/>
0 % output setting		4.0000 mA 0.0000 V 0.0000 V	Specify within settable range in the table 2.	<input type="checkbox"/>
100 % output setting		20.0000 mA 5.0000 V 10.0000 V		

[Table 1]

INPUT RANGE	MIN. SPAN	SETTABLE RANGE
Current input	2 mA	0.0000 to 50.0000 mA DC
Voltage input	100 mV	-1000.00 to +1000.00 mV DC
	1 V	-10.0000 to +10.0000 V DC

[Table 2]

Output Range	Minimum Span	Setting Range
Current output	1 mA	0.0000 to 23.0000 mA DC
Voltage output	500 mV	-5.7500 to +5.7500 V DC
	1 V	11.5000 to +11.5000 V DC