

ORDERING INFORMATION

MODEL : KS2V2

PLEASE FILL IN THIS SECTION



Model
Company
Name
P/O No.

FACTORY USE ONLY



Job No.	Approved by (Sales office)
Ser No.	Issued by (Sales office)
Sales	Approved by (Factory)
	Set by (Factory)

Specify the items you want to change. Default setting will be used if not specified.

Ser No. _____

DEFAULT shows values in case of nothing specified.

SETTING

PARAMETER BLOCK	NAME	UNIT	AVAILABLE VALUE	EXPLANATIONS	DEFAULT VALUE	SET VALUE	Factory Internal check
1	ST1	Engineering unit *1	-5 to +105% FS	Alarm setpoint value SET1	100.0		<input type="checkbox"/> Checked
	ST2	Engineering unit *1	-5 to +105% FS	Alarm setpoint value SET2	0.0		<input type="checkbox"/> Checked
2	HYS1	Deviative engineering unit *1	0 to 102% FS	Deadband (hysteresis) for SET1	1.0		<input type="checkbox"/> Checked
	HYS2	Deviative engineering unit *1	0 to 102% FS	Deadband (hysteresis) for SET2	1.0		<input type="checkbox"/> Checked
	P-SL	Engineering unit *1	-1999 to 9999	Scaling, lower range	0.0		<input type="checkbox"/> Checked
	P-SU	Engineering unit *1	-1999 to 9999	Scaling, upper range	100.0		<input type="checkbox"/> Checked
	P-dp	N/A	0,1,2 *2	Decimal point position	1		<input type="checkbox"/> Checked
	P-A1	N/A	0 to 8	Alarm mode for SET1 See Table 1.	1		<input type="checkbox"/> Checked
	P-A2	N/A	0 to 8	Alarm mode for SET2 See Table 1.	2		<input type="checkbox"/> Checked
	bUrn	N/A	H,L	Burnout protection (upscale or downscale)	H		<input type="checkbox"/> Checked
	P-d1	Seconds	1 to 10	Switching delay timer for SET1	1		<input type="checkbox"/> Checked
	P-d2	Seconds	1 to 10	Switching delay timer for SET2	1		<input type="checkbox"/> Checked
3	P-df	Seconds	0.0 to 900.0	Time constant for the input filter	5.0		<input type="checkbox"/> Checked
	P-d0	Seconds	0 to 20	Power ON delay time	0		<input type="checkbox"/> Checked

*1 Parameters set with "Engineering unit" or "Deviative engineering unit" shift according to changes in P-SL or P-SU setting.

*2 0 for XXXX (no decimal point), 1 for XXX.X (one-place decimal), 2 for XX.XX (two-place decimal).

Table 1 ALARM MODE v.s. PARAMETER CODE NO.

PARAMETER CODE (P-A1) (P-A2)	ALARM MODES			
	TRIP OPERATION	SET VALUE	LATCHING HOLD *1	RELAY & LED BEHAVIOR IN TRIPPED CONDITIONS
0	No alarm	—	—	—
1	High	Absolute value	Without	LED ON Coil energized
2	Low	Absolute value	Without	LED ON Coil energized
3	High	Absolute value	With	LED ON Coil energized
4	Low	Absolute value	With	LED ON Coil energized
5	High	Absolute value	Without	LED ON Coil de-energized
6	Low	Absolute value	Without	LED ON Coil de-energized
7	High	Absolute value	With	LED ON Coil de-energized
8	Low	Absolute value	With	LED ON Coil de-energized

*1 Without latching hold function, the unit is tripped upon starting operation when the unit is set to Low alarm. With the function, the unit is NOT tripped until the input goes once above and then below the setpoint.