

ORDERING INFORMATION

Model : DM05R

PLEASE FILL IN THIS SECTION



Model	Job No.	Approved by (Sales office)
Company	Ser No.	Issued by (Sales office)
Name	Sales Rep.	Approved by (Factory)
P/O No.		Issued by (Factory)
		Ser No.

FACTORY USE ONLY



■ INSTRUCTION

Select an option or specify the value within the allowable range for the item to be changed from the standard setting. The standard setting will be applied if not specified.

ITEM	STANDARD SETTING	EX-FACTORY	FACTORY INTERNAL CHECK
■ Action Reverse Input 4 mA DC, output stem rotates right (clockwise) and stops at full-open position (Input 1 V DC, output stem rotates right (clockwise) and stops at full-open position)	Reverse	<input type="checkbox"/> Reverse <input type="checkbox"/> Direct	<input type="checkbox"/>
Direct Input 20 mA DC, output stem rotates right (clockwise) and stops at full-open position (Input 5 V DC, output stem rotates right (clockwise) and stops at full-open position)			
■ Stem operation at low input *1	Hold position	<input type="checkbox"/> Hold position <input type="checkbox"/> Stop at full-close position <input type="checkbox"/> Stop at full-open position	<input type="checkbox"/>
■ Resolution *1	1 / 200	<input type="checkbox"/> 1 / 200 <input type="checkbox"/> 1 / 400	<input type="checkbox"/>
■ Restart limiting timer *1	0.2 sec.	<input type="checkbox"/> 0.2 sec. <input type="checkbox"/> 0.5 sec. <input type="checkbox"/> 1 sec. <input type="checkbox"/> 1.5 sec. <input type="checkbox"/> 2 sec.	<input type="checkbox"/>

*1 The items excluding the action cannot be changed by the user.