

ORDERING INFORMATION

MODEL : R7E-YV2

PLEASE FILL IN THIS SECTION



Model
Company
Name
P/O No.

FACTORY USE ONLY



Job No.	Approved by (Sales office)
Ser No.	Issued by (Sales office)
Sales	Approved by (Factory)
	Set by (Factory)
	Ser No.

Specify the items you want to change. Default setting will be used if not specified.

DEFAULT shows values in case of nothing specified.

■ ETHERNET PARAMETERS

ITEM	AVAILABLE VALUE	SET VALUE				DEFAULT VALUE	Factory Internal check
IP Address	0 to 255 (integer)					192.168.0.1	☐
Subnet Mask						255.255.255.0	☐
Default Gateway						192.168.0.100	☐
Linger	0 to 32767 (integer)					1800	☐
TCP Socket closed after no communication (Set 1800 for 180.0 sec.) for the preset time.						1800	
						1800	
						1800	

■ OUTPUT AT THE LOSE OF COMMUNICATION (BASIC MODULE)

ITEM	SET VALUE	DEFAULT VALUE	Factory Internal check
OUTPUT AT THE LOSE OF COMMUNICATION	☐ Hold the output (maintains the last data received normally)	Hold the output	☐
	☐ Reset the output (to -15% or approx. -11.5V DC)		

■ EXTENSION

ITEM	SET VALUE	DEFAULT VALUE	Factory Internal check
EXTENSION	☐ No extension	No extension	☐
	☐ Discrete input, 8 points / 16 points		
	☐ Discrete output, 8 points / 16 points		

■ OUTPUT AT THE LOSE OF COMMUNICATION (EXTENSION MODULE)

ITEM	SET VALUE	DEFAULT VALUE	Factory Internal check
OUTPUT AT THE LOSE OF COMMUNICATION	☐ Hold the output (maintains the last data received normally)	Hold the output	☐
	☐ Reset the output (turned off)		

■ OUTPUT RANGE SETTING (APPLIES TO BOTH CHANNELS)

ITEM	SET VALUE	DEFAULT VALUE	Factory Internal check
OUTPUT RANGE *1	☐ -10 — +10V DC	-10 — +10V DC	☐
	☐ -5 — +5V DC		
	☐ -1 — +1V DC		
	☐ 0 — 10V DC		
	☐ 0 — 5V DC		
	☐ 1 — 5V DC		
	☐ 0 — 1V DC		
	☐ -0.5 — +0.5V DC		
	☐ PC Configurator setting		

*1. When you want to set each channel independently, select "PC Configuration setting", then specify each channel in "INPUT RANGE SETTING (INDEPENDENT RANGE PER CHANNEL)".

■ OUTPUT RANGE SETTING (INDEPENDENT RANGE PER CHANNEL)

CHANNEL	SET VALUE	DEFAULT VALUE	Factory Internal check
INPUT 0 *2	☐ -10 — +10V DC	-10 — +10V DC	☐
	☐ -5 — +5V DC		
	☐ -1 — +1V DC		
	☐ 0 — 10V DC		
	☐ 0 — 5V DC		
	☐ 1 — 5V DC		
	☐ 0 — 1V DC		
	☐ -0.5 — +0.5V DC		
INPUT 1 *2	☐ -10 — +10V DC	-10 — +10V DC	☐
	☐ -5 — +5V DC		
	☐ -1 — +1V DC		
	☐ 0 — 10V DC		
	☐ 0 — 5V DC		
	☐ 1 — 5V DC		
	☐ 0 — 1V DC		
	☐ -0.5 — +0.5V DC		

*2. Specify "0 - 10V DC" for unused channel.

■ SCALING

Set zero and full scale to each channel (zero scale to full scale)

CHANNEL	AVAILABLE VALUE	SET VALUE	DEFAULT VALUE	Factory Internal check
OUTPUT 0	-32000 to +32000	to	0 to 10000	☐
OUTPUT 1	-32000 to +32000	to	0 to 10000	☐