

ORDERING INFORMATION

MODEL : R7HL-YV2

PLEASE FILL IN THIS SECTION



Model
Company
Name
P/O No.

FACTORY USE ONLY



Job No.	Approved by (Sales office)
Ser No.	Issued by (Sales office)
Sales	Approved by (Factory)
	Set by (Factory)

Specify the items you want to change. Default setting will be used if not specified.
 DEFAULT shows values in case of nothing specified.

■ OUTPUT RANGE SETTING (APPLIES TO ALL 4 CHANNELS)

ITEM	SET VALUE	DEFAULT VALUE	Factory Internal check
OUTPUT RANGE *1	<input type="checkbox"/> -10 - +10V DC	-10 - +10V DC	<input type="checkbox"/>
	<input type="checkbox"/> -5 - +5V DC		
	<input type="checkbox"/> -1 - +1V DC		
	<input type="checkbox"/> 0 - 10V DC		
	<input type="checkbox"/> 0 - 5V DC		
	<input type="checkbox"/> 1 - 5V DC		
	<input type="checkbox"/> 0 - 1V DC		
	<input type="checkbox"/> -0.5 - +0.5V DC		
	<input type="checkbox"/> PC Configurator setting		

*1. When you want to set each channel independently, Select "PC Configuration setting," then specify each channel in "OUTPUT RANGE SETTING (INDEPENDENT RANGE PER CHANNEL)."

■ OUTPUT RANGE SETTING (INDEPENDENT RANGE PER CHANNEL)

CHANNEL	SET VALUE	DEFAULT VALUE	Factory Internal check
OUTPUT 0 *2	<input type="checkbox"/> -10 - +10V DC	-10 - +10V DC	<input type="checkbox"/>
	<input type="checkbox"/> -5 - +5V DC		
	<input type="checkbox"/> -1 - +1V DC		
	<input type="checkbox"/> 0 - 10V DC		
	<input type="checkbox"/> 0 - 5V DC		
	<input type="checkbox"/> 1 - 5V DC		
	<input type="checkbox"/> 0 - 1V DC		
	<input type="checkbox"/> -0.5 - +0.5V DC		
	OUTPUT 1 *2		
<input type="checkbox"/> -5 - +5V DC			
<input type="checkbox"/> -1 - +1V DC			
<input type="checkbox"/> 0 - 10V DC			
<input type="checkbox"/> 0 - 5V DC			
<input type="checkbox"/> 1 - 5V DC			
<input type="checkbox"/> 0 - 1V DC			
<input type="checkbox"/> -0.5 - +0.5V DC			

*2. Specify "0 - 10 V DC" for unused channel.

■ OUTPUT AT THE LOSE OF COMMUNICATION

ITEM	SET VALUE	DEFAULT VALUE	Factory Internal check
OUTPUT AT THE LOSE OF COMMUNICATION	<input type="checkbox"/> Hold the output (maintains the last data received normally)	Hold the output	<input type="checkbox"/>
	<input type="checkbox"/> Reset the output (to -15% or approx. -11.5V DC)		

■ TRANSFER RATE

ITEM	SET VALUE	DEFAULT VALUE	Factory Internal check
TRANSFER RATE	<input type="checkbox"/> 12Mbps	12Mbps	<input type="checkbox"/>
	<input type="checkbox"/> 6Mbps		

■ STATION ADDRESS

AVAILABLE VALUE	SET VALUE	DEFAULT VALUE	Factory Internal check
01H to 3E (hexadecimal)		01H	<input type="checkbox"/>

■ SCALING

Set zero and full scale to each channel (zero scale to full scale)

CHANNEL	AVAILABLE VALUE	SET VALUE	DEFAULT VALUE	Factory Internal check
OUTPUT 0	-32000 to +32000	to	0 to 10000	<input type="checkbox"/>
OUTPUT 1	-32000 to +32000	to	0 to 10000	<input type="checkbox"/>