

# ORDERING INFORMATION

# MODEL : R3-YS4, R3S-YS4, R3Y-YS4

## PLEASE FILL IN THIS SECTION



Model
Company
Name
P/O No.

## FACTORY USE ONLY



Job No.	Approved by (Sales office)
Ser No.	Issued by (Sales office)
Sales	Approved by (Factory)
	Set by (Factory)
	Ser No.

**Specify the items you want to change. Default setting will be used if not specified.**  
 DEFAULT shows values in case of nothing specified.

### ■ UNUSED OUTPUT

CHANNEL	SET VALUE	Factory Internal check
OUTPUT 1	<input type="checkbox"/> UNUSED	<input type="checkbox"/>
OUTPUT 2	<input type="checkbox"/> UNUSED	<input type="checkbox"/>
OUTPUT 3	<input type="checkbox"/> UNUSED	<input type="checkbox"/>
OUTPUT 4	<input type="checkbox"/> UNUSED	<input type="checkbox"/>

### ■ OUTPUT AT THE LOSS OF COMMUNICATION

CHANNEL	SET VALUE	DEFAULT VALUE	Factory Internal check
OUTPUT 1 to 4	<input type="checkbox"/> OUTPUT HOLD	OUTPUT HOLD	<input type="checkbox"/>
	<input type="checkbox"/> OUTPUT OFF		

### ■ OUTPUT HOLD or OUTPUT OFF

In normal conditions, the module outputs the signal from the preferred bus A. When an error is detected, the output is switched to the data from the bus B.

▪ Output Hold

If both are in error, the module holds the signal and stands by until one of the communications recovers.

▪ Output OFF

If both are in error, the module outputs -15 % and stands by until one of the communications recovers.

At the startup, it outputs -15 % until the communication is established and normal data is received.

### ■ DATA RANGE

Set zero and full scale to each channel (zero scale to full scale)

CHANNEL	AVAILABLE VALUE	SET VALUE	DEFAULT VALUE	Factory Internal check
OUTPUT 1	-32000 to 32000	to	0 to 10000	<input type="checkbox"/>
OUTPUT 2	-32000 to 32000	to	0 to 10000	<input type="checkbox"/>
OUTPUT 3	-32000 to 32000	to	0 to 10000	<input type="checkbox"/>
OUTPUT 4	-32000 to 32000	to	0 to 10000	<input type="checkbox"/>