

ORDERING INFORMATION

MODEL : R3-NF2

PLEASE FILL IN THIS SECTION



Model
Company
Name
P/O No.

FACTORY USE ONLY



Job No.	Approved by (Sales office)
Ser No.	Issued by (Sales office)
Sales	Approved by (Factory)
	Set by (Factory)
Ser No. _____	

Specify the items you want to change. Default setting will be used if not specified.

DEFAULT shows values in case of nothing specified.

■ T-Link SETTINGS

ITEM	SET VALUE	DEFAULT VALUE	Factory Internal check
NODE ADDRESS Address range: 00 – 99		00	<input type="checkbox"/>

■ FUNCTION SETTINGS

ITEM	SET VALUE	DEFAULT VALUE	Factory Internal check
MAIN network / SUB network For single communication, the network module must always be set to 'MAIN'.	<input type="checkbox"/> MAIN <input type="checkbox"/> SUB	MAIN	<input type="checkbox"/>
Input Error Data Hold: When the communication from an input module is lost due to the input module error, the network module holds the signal and stands by until the communication recovers. Set to '0': When the communication from an input module is lost due to the input module error, the network module outputs '0.'	<input type="checkbox"/> Hold <input type="checkbox"/> Set to '0'	Hold	<input type="checkbox"/>
LED Function RUN / ERROR indication mode RUN LED green when normal ERR LED green when abnormal RD / SD indication mode RUN LED red when receiving ERR LED red when transmitting	<input type="checkbox"/> RUN / ERROR <input type="checkbox"/> RD / SD	RUN / ERROR	<input type="checkbox"/>