

# ORDERING INFORMATION

# MODEL : R30YS4

## PLEASE FILL IN THIS SECTION



Model
Company
Name
P/O No.

## FACTORY USE ONLY



Job No.	Approved by (Sales office)
Ser No.	Issued by (Sales office)
Sales	Approved by (Factory)
	Set by (Factory)
	Ser No.

**Specify the items you want to change. Default setting will be used if not specified.**

DEFAULT shows values in case of nothing specified.

### ■ OUTPUT RANGE SETTING

CHANNEL	SET VALUE	DEFAULT VALUE	Factory Internal check
OUTPUT 1	<input type="checkbox"/> 4 to 20mA DC	4 to 20mA DC	<input type="checkbox"/>
	<input type="checkbox"/> CH Disable		
OUTPUT 2	<input type="checkbox"/> 4 to 20mA DC	4 to 20mA DC	<input type="checkbox"/>
	<input type="checkbox"/> CH Disable		
OUTPUT 3	<input type="checkbox"/> 4 to 20mA DC	4 to 20mA DC	<input type="checkbox"/>
	<input type="checkbox"/> CH Disable		
OUTPUT 4	<input type="checkbox"/> 4 to 20mA DC	4 to 20mA DC	<input type="checkbox"/>
	<input type="checkbox"/> CH Disable		

Default value for CH Disable.

### ■ DATA RANGE

Set zero and full scale to each channel (zero scale to full scale)

CHANNEL	AVAILABLE VALUE	SET VALUE	DEFAULT VALUE	Factory Internal check
OUTPUT 1	-32000 to +32000	to	0 to 10000	<input type="checkbox"/>
OUTPUT 2	-32000 to +32000	to	0 to 10000	<input type="checkbox"/>
OUTPUT 3	-32000 to +32000	to	0 to 10000	<input type="checkbox"/>
OUTPUT 4	-32000 to +32000	to	0 to 10000	<input type="checkbox"/>

### ■ OUTPUT RANGE AT COMMUNICATION FAILURE OR POWER UP

CHANNEL	AVAILABLE VALUE	SET VALUE	DEFAULT VALUE	Factory Internal check
OUTPUT 1	-15.00 to +115.00		-15.00	<input type="checkbox"/>
OUTPUT 2	-15.00 to +115.00		-15.00	<input type="checkbox"/>
OUTPUT 3	-15.00 to +115.00		-15.00	<input type="checkbox"/>
OUTPUT 4	-15.00 to +115.00		-15.00	<input type="checkbox"/>

### ■ OUTPUT AT THE LOSS OF COMMUNICATION

ITEM	AVAILABLE VALUE	DEFAULT VALUE	Factory Internal check
OUTPUT AT THE LOSS OF COMMUNICATION	<input type="checkbox"/> Hold the output data	Hold the output data	<input type="checkbox"/>
	<input type="checkbox"/> User set data output		